

852872

County Becker

Quad

Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date

Update Date01/14/2021

Received Date10/22/2020

Well Name	Township	Range	Dir	Section	Subsection	Well Depth	Depth Completed	Date Well Completed					
RHODE, DAVID	141	36	W	12	CCC	62 ft.	62 ft.	10/06/2020					
Elevation	Elev. Method					Drill Method	Non-specified Rotary	Drill Fluid	Bentonite				
Address						Use	domestic	Status	Active				
Well						32267 50 CO PARK RAPIDS MN 56470							
Stratigraphy Information						Well Hydrofractured?	Yes	☐	No	☒	From	To	
Geological Material						Casing Type	Single casing		Joint				
TOP SOIL						Drive Shoe?	Yes	☐	No	☒	Above/Below		
SAND						Casing Diameter	Weight		Hole Diameter				
SAND						4 in. To	58 ft.	1	lbs./ft.	6.7 in. To 62 ft.			
SAND													
SAND													
						Open Hole	From	ft.	To	ft.			
						Screen?	☒	Type	stainless	Make	JOHNSON		
						Diameter	Slot/Gauze	Length	Set				
						4 in.	15	4 ft.	58 ft.	62 ft.			
						Static Water Level							
						18 ft.	land surface	Measure	10/06/2020				
						Pumping Level (below land surface)							
						57 ft.	1 hrs.	Pumping at	30	g.p.m.			
						Wellhead Completion							
						Pitless adapter manufacturer	SNAPPY		Model	MONITOR			
						☐ Casing Protection	☒ 12 in. above grade						
						☐ At-grade (Environmental Wells and Borings ONLY)							
						Grouting Information							
						Well Grouted?	☒	Yes	☐	No	☐	Not Specified	
						Material	Amount		From	To			
						bentonite	4	Sacks	0	ft.	50	ft.	
						Nearest Known Source of Contamination							
						100 feet	Southeas Direction		Septic tank/drain field	Type			
						Well disinfected upon completion?							
						☒	Yes	☐	No				
						Pump	☐	Not Installed	Date Installed	06/19/2020			
						Manufacturer's name							
						PENTEK							
						Model Number	4JP07221	HP	0.75	Volt	230		
						Length of drop pipe	40	ft	Capacity	10	g.p.	Typ	Submersible
						Abandoned							
						Does property have any not in use and not sealed well(s)?							
						☐	Yes	☒	No				
						Variance							
						Was a variance granted from the MDH for this well?							
						☐	Yes	☒	No				
						Miscellaneous							
						First Bedrock	Aquifer						
						Last Strat	Depth to Bedrock		ft				
						Located by							
						Locate Method							
						System	UTM - NAD83, Zone 15, Meters		X	Y			
						Unique Number Verification							
						Input Date							
						Angled Drill Hole							
						Well Contractor							
						Elsner Well Drilling, Inc.	1374		ELSNER, KELLY				
						Licensee Business		Lic. or Reg. No.		Name of Driller			