

853261

County Crow Wing
Quad Trommald
Quad ID 231D

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date07/16/2021
Update Date06/12/2025
Received Date05/20/2021

Well Name WALBURG, JON	Township 47	Range 29	Dir W	Section 31	Subsection BCDBAB	Well Depth 89 ft.	Depth Completed 89 ft.	Date Well Completed 04/06/2021
Elevation 1181.1	Elev. Method LiDAR 1m DEM (MNDNR)					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Contact 68 MONARCH WA NORTH OAKS MN 55127						Well Hydrofractured? Yes ☐ No ☒ From To		
Well 24661 N. BLACKBEAR LA CROSBY MN 56441						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
SAND		0	6	BROWN	SOFT	4 in. To 69 ft. 1.88 lbs./ft. 8.7 in. To 89 ft.		
SAND		6	40	GRAY	SOFT			
CLAY		40	65	GRAY	MEDIUM			
SAND/GRAVEL		65	88	BROWN	MEDIUM			
GRAVEL		88	89	GREEN	HARD			
						Open Hole From ft. To ft.		
						Screen? ☒ Type plastic Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						4 in. 16 20 ft. 69 ft. 89 ft.		
						Static Water Level		
						3 ft. land surface Measure 04/06/2021		
						Pumping Level (below land surface)		
						89 ft. 1 hrs. Pumping at 85 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer BAKER Model BOLT-ON		
						☐ Casing Protection ☐ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						bentonite 4 Sacks ft. 50 ft.		
						Nearest Known Source of Contamination		
						55 feet Southwes Direction Sewer Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☐ Not Installed Date Installed 04/06/2021		
						Manufacturer's name GRUNDFOS		
						Model Number 10S007-200 HP 0.75 Volt 220		
						Length of drop pipe 40 ft Capacity 15 g.p. Typ Submersible		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by Minnesota Department of Health		
						Locate Method Digitization (Screen) - Map (1:24,000) (15 meters or		
						System UTM - NAD83, Zone 15, Meters X 418746 Y 5151606		
						Unique Number Verification Address with parcel Input Date 06/12/2025		
						Angled Drill Hole		
						Well Contractor		
						Lambert Water Wells, Inc. 2119 LAMBERT, LORE		
						Licensee Business Lic. or Reg. No. Name of Driller		