

854373

County Wright

Quad

Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date05/04/2026

Update Date05/04/2026

Received Date01/29/2026

Well Name LUEGERS, RAY	Township 120	Range 24	Dir W	Section 29	Subsection ABC	Well Depth 78 ft.	Depth Completed 70 ft.	Date Well Completed 09/22/2025
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid Bentonite		
Address						Use domestic	Status Active	
C/W 7617 20TH ST NE ST MICHAEL MN 55376						Well Hydrofractured? Yes ☐ No ☒	From	To
Stratigraphy Information						Casing Type Single casing	Joint Glued	
						Drive Shoe? Yes ☐ No ☒	Above/Below	
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter		
TOP SOIL		0	4	BLACK	SOFT	Weight		
CLAY		4	21	TAN	SOFT	Hole Diameter		
CLAY + GRAVEL		21	34	GRAY	SOFT	4 in. To 65 ft. 1.9 lbs./ft.		
SAND + GRAVEL		34	78	VARIED	SOFT	6.7 in. To 78 ft.		
						Open Hole	From	To
						Screen? ☒	Type plastic	Make JOHNSON
						Diameter	Slot/Gauze	Length
						4 in.	20	10 ft. 65 ft. 70 ft.
						Static Water Level		
						31 ft.	land surface	Measure 09/22/2025
						Pumping Level (below land surface)		
						65 ft.	2 hrs.	Pumping at 75 g.p.m.
						Wellhead Completion		
						Pitless adapter manufacturer	MONITOR	Model SNAPPY
						☐ Casing Protection	☒ 12 in. above grade	
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information	Well Grouted? ☒ Yes ☐ No ☐ Not Specified	
						Material	Amount	From To
						high solids bentonite	5 Sacks	ft. 50 ft.
						Nearest Known Source of Contamination		
						52 feet	West Direction	Sewer Type
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☐ Not Installed	Date Installed	09/22/2025
						Manufacturer's name FRANKLIN		
						Model Number	HP	Volt
						10FS05	0.5	230
						Length of drop pipe	ft	Capacity
						40	12 g.p.	Typ Submersible
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock	Aquifer	
						Last Strat	Depth to Bedrock	ft
						Located by		
						Locate Method		
						System	UTM - NAD83, Zone 15, Meters	X Y
						Unique Number Verification		
						Input Date		
						Angled Drill Hole		
						Well Contractor		
						Alberg Water Services, Inc.	2423	ALBERG, G
						Licensee Business	Lic. or Reg. No.	Name of Driller