

854375

County Wright
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/04/2026
Update Date 05/04/2026
Received Date 01/29/2026

Well Name MORTON	Township 118	Range 27	Dir W	Section 8	Subsection DBC
Elevation	Elev. Method				
Address					
Well 76XX KILLBURY AV SW HOWARD LAKE MN 55349					
Contact 113 THOMAS PARK DR MONTICELLO MN 55362					
Stratigraphy Information					
Geological Material		From	To (ft.)	Color	Hardness
CLAY		0	26	BROWN	SOFT
SAND GRAVEL + CLAY		26	33	BROWN	SOFT
CLAY + GRAVEL		33	88	GRAY	SOFT
SAND + GRAVEL		88	111	VARIED	SOFT
CLAY		111	117	GRAY	
Well Depth 117 ft. Depth Completed 109 ft. Date Well Completed 11/12/2025					
Drill Method		Non-specified Rotary		Drill Fluid Bentonite	
Use domestic				Status Active	
Well Hydrofractured? Yes ☐ No ☒ From To					
Casing Type Single casing Joint Glued					
Drive Shoe? Yes ☐ No ☒ Above/Below					
Casing Diameter		Weight		Hole Diameter	
4 in. To 104 ft. 1.9 lbs./ft.				6.7 in. To 117 ft.	
Open Hole From ft. To ft.					
Screen? ☒ Type plastic Make JOHNSON					
Diameter		Slot/Gauze		Length Set	
4 in. 20		5 ft.		104 ft. 109 ft.	
Static Water Level					
22 ft.		land surface		Measure 11/12/2025	
Pumping Level (below land surface)					
85 ft.		2 hrs. Pumping at		100 g.p.m.	
Wellhead Completion					
Pitless adapter manufacturer		MONITOR		Model SNAPPY	
☐ Casing Protection		☒ 12 in. above grade			
☐ At-grade (Environmental Wells and Borings ONLY)					
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
Material		Amount		From To	
high solids bentonite		5 Sacks		ft. 5 ft.	
Nearest Known Source of Contamination					
50 feet		North Direction		Septic tank/drain field Type	
Well disinfected upon completion? ☒ Yes ☐ No					
Pump ☐ Not Installed Date Installed 11/12/2025					
Manufacturer's name FRANKLIN					
Model Number		HP		Volt	
10ES05		0.5		230	
Length of drop pipe		ft		Capacity g.p. Typ Submersible	
40				12 g.p. Submersible	
Abandoned					
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No					
Variance					
Was a variance granted from the MDH for this well? ☐ Yes ☒ No					
Miscellaneous					
First Bedrock		Aquifer			
Last Strat		Depth to Bedrock		ft	
Located by					
Locate Method					
System		UTM - NAD83, Zone 15, Meters		X Y	
Unique Number Verification				Input Date	
Angled Drill Hole					
Well Contractor					
Alberg Water Services, Inc.		2423		ALBERG, G	
Licensee Business		Lic. or Reg. No.		Name of Driller	