

854646

County Anoka
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 06/01/2023
Update Date 06/01/2023
Received Date 11/29/2021

Well Name DAVISON, PAUL	Township 32	Range 23	Dir W	Section 14	Subsection CAB	Well Depth 96 ft.	Depth Completed 90 ft.	Date Well Completed 09/27/2021
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Contact 3480 126TH CI NE BLAINE MN 55449						Well Hydrofractured? Yes ☐ No ☒ From To		
Well 4013 160TH AV NE HAM LAKE MN						Casing Type Step down Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter 5 in. To 80 ft. lbs./ft. 7.8 in. To ft.		
TOP SOIL		0	1			5 in. To 60 ft. lbs./ft. 7.8 in. To ft.		
FINE SAND		1	57					
FINE SAND/ CLAY		57	67	GRAY				
SAND & GRAVEL		67	92					
SHALE		92	96					
Open Hole						From	ft.	To
Screen? ☒						Type plastic	Make JOHNSON	
Diameter						Slot/Gauze	Length	Set
5 in.						10	10 ft.	80 ft. 90 ft.
Static Water Level								
17 ft.						land surface	Measure	08/25/2021
Pumping Level (below land surface)								
75 ft.						4 hrs.	Pumping at	40 g.p.m.
Wellhead Completion								
Pitless adapter manufacturer						MERRILL	Model	MCK
☐ Casing Protection						☐ 12 in. above grade		
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
Material						Amount	From	To
bentonite						6 Sacks	ft.	70 ft.
Nearest Known Source of Contamination								
70 feet						Southwes	Direction	Sewer Type
Well disinfected upon completion?						☒ Yes ☐ No		
Pump ☐ Not Installed						Date Installed	09/27/2021	
Manufacturer's name						GOULDS (3 PHASE)		
Model Number						18CS10	HP	1
Length of drop pipe						40 ft	Capacity	18 g.p.
Abandoned								
Does property have any not in use and not sealed well(s)?						☐ Yes ☒ No		
Variance								
Was a variance granted from the MDH for this well?						☐ Yes ☒ No		
Miscellaneous								
First Bedrock						Aquifer		
Last Strat						Depth to Bedrock		
Located by						ft		
Locate Method								
System						UTM - NAD83, Zone 15, Meters	X	Y
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor								
Thein Well Co., Inc.						1337	DREXLER, M	
Licensee Business						Lic. or Reg. No.	Name of Driller	