Minnesota Unique Well Number

855882

County Todd
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT

Entry Date
Update Date 08/03/2021
Received Date 06/21/2021

Well Name	Township	Range	Dir	Section	Subsection
GRAVES, TYLER	129	33	W	30	DBD

Elevation **Elev. Method**

Address

C/W 22092 GOODWILL DR LONG PRAIRIE MN

Stratigraphy Information

Geological Material	From	To (ft.)	Color	Hardness
TOP SOIL	0	1	BLACK	SOFT
CLAY ROCKS	1	38	BROWN	HARD
CLAY	38	61	GRAY	MEDIUM
SAND GRAVEL ROCKS	61	64	GRAY	MEDIUM
CLAY	64	87	GRAY	HARD
SAND GRAVEL	87	98	GRAY	MEDIUM
CLAY	98	105	BROWN	HARD
CLAY ROCKS	105	139	GRAY	HARD
CLAY	139	144	RED	HARD
FINE SAND	144	152	GRAY	MEDIUM

Remarks

Well Depth	Depth Completed	Date Well Completed
152 ft.	152 ft.	05/06/2021

Drill Method Non-specified Rotary **Drill Fluid** Bentonite

Use domestic **Status** Active

Well Hydrofractured? **Yes** ☐ **No** ☐ **From** **To**

Casing Type Single casing **Joint**
Drive Shoe? **Yes** ☐ **No** ☐ **Above/Below**

Casing Diameter	Weight	Hole Diameter
4 in. To 144 ft.	2.3 lbs./ft.	7.7 in. To 152 ft.

Open Hole From ft. To ft.

Screen? ☒ **Type** telescoping **Make** JOHNSON

Diameter	Slot/Gauze	Length	Set Between
4 in.	15	8 ft.	144 ft. 152 ft.

Static Water Level
43 ft. land surface Measure Date 05/06/2021

Pumping Level (below land surface)
144 ft. after 2 hrs. Pumping at 200 g.p.m.

Wellhead Completion
Pitless adapter manufacturer Model
☐ Casing Protection ☒ 12 in. above grade
☐ At-grade (Environmental Wells and Borings ONLY)

Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified

Material	Amount	From	To
high solids bentonite		ft.	50 ft.

Nearest Known Source of Contamination
54 feet South Direction Septic tank/drain field Type
Well disinfected upon completion? ☒ Yes ☐ No

Pump ☐ Not Installed Date Installed 05/12/2021
Manufacturer's name GRUNDFOS
Model Number CONSTANTP HP 1.5 Volt 230
Length of drop pipe 80 ft Capacity g.p.m. Type Submersible

Abandoned Wells
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No

Variance
Was a variance granted from the MDH for this well? ☐ Yes ☒ No

Miscellaneous
First Bedrock Aquifer
Last Strat Depth to Bedrock ft.
Located by
Locate Method
System UTM - NAD83, Zone 15, Meters X Y
Unique Number Verification Input Date

Angled Drill Hole

Well Contractor Certification
Klimek Bros. Well Drilling, Inc. 1864 KLIMEK, D
Licensee Business Name Lic. or Reg. No. Name of Driller