

857796

County Houston
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date

Update Date06/11/2024

Received Date01/19/2024

Well Name DOUCET,	Township 103	Range 5	Dir W	Section 26	Subsection BBA	Well Depth 598 ft.	Depth Completed 598 ft.	Date Well Completed 12/14/2023	
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid		
Address C/W10019 WINDWALKER RD CALEDONIA MN 55921						Use domestic	Status Active		
						Well Hydrofractured? Yes ☐ No ☒		From To	
Stratigraphy Information Geological MaterialFromTo (ft.)ColorHardness SANDY CLAY045BROWNSOFT DOLOMITE45198GRAYMEDIUM SANDSTONE198300BROWNSOFT SHALY DOLOMITE300358GRAYMEDIUM SHALE & SANDSTONE358505GREENMEDIUM SANDSTONE505598GRAYMEDIUM						Casing Type Single casing	Joint Welded		
						Drive Shoe? Yes ☒ No ☐		Above/Below	
						Casing Diameter 4 in. To		Weight ft. 551 lbs./ft.	Hole Diameter 8 in. To 551 ft. 4 in. To 598 ft.
						Open Hole From 551 ft. To 598 ft.			
						Screen? ☐		Type	Make
						Static Water Level 422 ft. land surface Measure 10/07/2023			
						Pumping Level (below land surface) ft. hrs. Pumping at g.p.m.			
						Wellhead Completion Pitless adapter manufacturer MONITOR Model 4"X6' ☐ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)			
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified MaterialAmountFromTo pearock4 Cubic yardsft. 300 ft. neat cement6.5 Cubic yardsft. 551 ft.			
						Nearest Known Source of Contamination feet Direction Type Well disinfected upon completion? ☒ Yes ☐ No			
Pump ☐ Not Installed Date Installed 12/14/2023 Manufacturer's name GOULDS Model Number 10GS20 HP 2 Volt 230 Length of drop pipe 442 ft Capacity 13 g.p. Typ Submersible									
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No									
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No									
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date									
Angled Drill Hole									
Well Contractor Rowland Well Co., Inc. 1928 ROWLAND, N Licensee Business Lic. or Reg. No. Name of Driller									