Minnesota Unique Well Number

857800

County Fillmore
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH

WELL AND BORING REPORT

Minnesota Statutes Chapter 1031

Entry Date 05/16/2025
Update Date 05/16/2025
Received Date 04/05/2024

Well Name	Township	Range	Dir	Section	Subsection
BORNTREGER,	103	13	W	11	CCA

Elevation **Elev. Method**

Address

C/W 26171 38 CR SPRING VALLEY MN

Stratigraphy Information

Geological Material	From	To (ft.)	Color	Hardness
CLAY	0	26	BROWN	SOFT
LIMESTONE	26	235	GRAY	MED-HRD
SHALE	235	277	BLUE	MEDIUM
LIMESTONE	277	299	BROWN	HARD
SHALE	299	307	GREEN	MEDIUM
SANDSTONE	307	393	GRAY	MEDIUM
DOLOMITE	393	393	GRAY	HARD

Remarks

Well Depth 393 ft. **Depth Completed** 393 ft. **Date Well Completed** 04/05/2024

Drill Method Non-specified Rotary **Drill Fluid**

Use domestic **Status** Active

Well Hydrofractured? **Yes** ☐ **No** ☒ **From** **To**

Casing Type Single casing **Joint** Welded

Drive Shoe? **Yes** ☒ **No** ☐ **Above/Below**

Casing Diameter			Weight		Hole Diameter		
4	in. To	352 ft.	10.79	lbs./ft.	8	in. To	352 ft.
					4	in. To	393 ft.

Open Hole From 352 ft. To 393 ft.

Screen? ☐ **Type** **Make**

Static Water Level

292 ft. land surface Measure 04/05/2024

Pumping Level (below land surface)

ft. hrs. Pumping at g.p.m.

Wellhead Completion

Pitless adapter manufacturer Model

☐ Casing Protection ☒ 12 in. above grade
☐ At-grade (Environmental Wells and Borings ONLY)

Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified

Material	Amount		From	To
pearock	2	Cubic yards	ft. 240	ft.
neat cement	5.5	Cubic yards	ft. 352	ft.

Nearest Known Source of Contamination

feet Direction Type

Well disinfected upon completion? ☒ Yes ☐ No

Pump ☒ Not Installed Date Installed

Manufacturer's name

Model Number HP Volt

Length of drop pipe ft Capacity g.p. Typ

Abandoned

Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No

Variance

Was a variance granted from the MDH for this well? ☐ Yes ☒ No

Miscellaneous

First Bedrock Aquifer

Last Strat Depth to Bedrock ft

Located by

Locate Method

System UTM - NAD83, Zone 15, Meters X Y

Unique Number Verification Input Date

Angled Drill Hole

Well Contractor

Rowland Well Co., Inc. 1928 ROWLAND, N

Licensee Business Lic. or Reg. No. Name of Driller