

859469

County Steele
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 01/16/2026
Update Date 01/16/2026
Received Date 07/28/2025

Well Name TROTMAN, TIM					Township 105	Range 19	Dir Section W 28	Subsection CBB	Well Depth 150 ft.		Depth Completed 150 ft.		Date Well Completed 09/01/2024	
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Qwik gel		
Address C/W 15377 54TH AV SE BLOOMING PRAIRIE MN									Use domestic		Status Active			
Stratigraphy Information Geological Material From To (ft.) Color Hardness SAND GRAVEL 0 35 BROWN SOFT SAND 35 135 GRAY SOFT LIMESTONE 135 150 TAN HARD									Well Hydrofractured? Yes ☐ No ☒		From		To	
									Casing Type Single casing		Joint Welded			
									Drive Shoe? Yes ☒ No ☐		Above/Below			
									Casing Diameter 5 in. To 137 ft.		Weight 15 lbs./ft.		Hole Diameter 9 in. To 137 ft. 5 in. To 150 ft.	
									Open Hole From 137 ft. To 150 ft.		Screen? ☐		Type Make	
									Static Water Level 40 ft. land surface Measure 09/01/2024					
									Pumping Level (below land surface) 60 ft. 2 hrs. Pumping at 40 g.p.m.					
									Wellhead Completion Pitless adapter manufacturer Model ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)					
									Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite 10 Sacks ft. 137 ft.					
									Nearest Known Source of Contamination 230 feet North Direction Septic tank/drain field Type Well disinfected upon completion? ☒ Yes ☐ No					
Pump ☒ Not Installed Date Installed Manufacturer's name Model Number HP Volt Length of drop pipe ft Capacity g.p. Typ														
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☐ No														
Variance Was a variance granted from the MDH for this well? ☐ Yes ☐ No														
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date														
Angled Drill Hole														
Well Contractor Arnies Pump Service and 2137 GOODNIGHT, M Licensee Business Lic. or Reg. No. Name of Driller														