

860164

County Morrison
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 07/22/2022
Received Date 03/09/2022

Well Name SEELLEN,	Township 131	Range 31	Dir W	Section 14	Subsection DBA	Well Depth 99 ft.	Depth Completed 99 ft.	Date Well Completed 12/15/2021
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Contact 9403 CABLE RD LITTLE FALLS MN 56345						Well Hydrofractured? Yes ☐ No ☒ From To		
Well N/A MARBLE DR CUSHING MN 56443						Casing Type Single casing Joint Welded		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material From To (ft.) Color Hardness						Casing Diameter Weight Hole Diameter		
CLAY AND GRAVEL 0 19 BROWN MEDIUM						4 in. To 94 ft. lbs./ft. 6.7 in. To 99 ft.		
SANDY CLAY 19 45 BROWN SFT-MED								
CLAY 45 59 BROWN MEDIUM								
SAND CLAY 59 86 GRAY MEDIUM								
SAND 86 99 GRAY SOFT								
						Open Hole From ft. To ft.		
						Screen? ☒ Type stainless Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						2 in. 15 5 ft. 94 ft. 99 ft.		
						Static Water Level		
						59 ft. land surface Measure 12/15/2021		
						Pumping Level (below land surface)		
						90 ft. 1 hrs. Pumping at 10 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer Model		
						☐ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						bentonite 3 Sacks ft. 60 ft.		
						Nearest Known Source of Contamination		
						50 feet Direction Septic tank/drain field Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☒ Not Installed Date Installed		
						Manufacturer's name		
						Model Number HP Volt		
						Length of drop pipe ft Capacity g.p. Typ		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						North Star Well Services, 3458 D SYPNIESKI		
						Licensee Business Lic. or Reg. No. Name of Driller		