

862934

County Crow Wing
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 08/02/2022
Received Date 03/09/2022

Well Name PERLINGER,	Township 136	Range 29	Dir W	Section 36	Subsection CBD
Elevation	Elev. Method				
Address					
Contact 1813 7TH ST N SARTELL MN 56377					
Well 5538 LADY SLIPPER DR PEQUOT LAKES MN 56472					
Stratigraphy Information					
Geological Material		From	To (ft.)	Color	Hardness
SAND		0	45	BROWN	MEDIUM
SAND AND GRAVEL		45	59	BROWN	MEDIUM
SAND		59	68	BROWN	SOFT
Well Depth 68 ft. Depth Completed 68 ft. Date Well Completed 11/02/2021					
Drill Method Non-specified Rotary		Drill Fluid Bentonite			
Use domestic				Status Active	
Well Hydrofractured? Yes ☐ No ☒ From To					
Casing Type Single casing		Joint Welded			
Drive Shoe? Yes ☐ No ☒		Above/Below			
Casing Diameter 4 in. To 63 ft.		Weight lbs./ft.		Hole Diameter 6.7 in. To 68 ft.	
Open Hole From ft. To ft.					
Screen? ☒		Type stainless		Make JOHNSON	
Diameter Slot/Gauze		Length		Set	
2 in. 15		5 ft.		63 ft. 68 ft.	
Static Water Level					
17 ft.		land surface		Measure 11/02/2021	
Pumping Level (below land surface)					
50 ft.		1 hrs. Pumping at		20 g.p.m.	
Wellhead Completion					
Pitless adapter manufacturer				Model	
☐ Casing Protection		☒ 12 in. above grade			
☐ At-grade (Environmental Wells and Borings ONLY)					
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
Material		Amount		From To	
bentonite		3.5 Sacks		ft. 50 ft.	
Nearest Known Source of Contamination					
50 feet		Direction		Septic tank/drain field Type	
Well disinfected upon completion?				☒ Yes ☐ No	
Pump ☒ Not Installed Date Installed					
Manufacturer's name					
Model Number		HP		Volt	
Length of drop pipe		ft Capacity		g.p. Typ	
Abandoned					
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No					
Variance					
Was a variance granted from the MDH for this well? ☐ Yes ☒ No					
Miscellaneous					
First Bedrock		Aquifer			
Last Strat		Depth to Bedrock		ft	
Located by					
Locate Method					
System		UTM - NAD83, Zone 15, Meters		X Y	
Unique Number Verification				Input Date	
Angled Drill Hole					
Well Contractor					
North Star Well Services,		3458		D SYPNIESKI	
Licensee Business		Lic. or Reg. No.		Name of Driller	
Remarks					