

865185

County Stevens

Quad

Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date12/08/2025

Update Date12/08/2025

Received Date11/03/2025

Well Name BOYS SUPPLY	Township 123	Range 41	Dir W	Section 30	Subsection CCC	Well Depth 294 ft.	Depth Completed 294 ft.	Date Well Completed 09/18/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
C/W 32686 460TH AV HANCOCK MN 56244						Well Hydrofractured? Yes ☐ No ☒ From To		
Stratigraphy Information						Casing Type Single casing Joint		
						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material						Casing Diameter		
From To (ft.) Color Hardness						Weight		
TOP SOIL						Hole Diameter		
CLAY						8 in. To 274 ft. lbs./ft. in. To 294 ft.		
CLAY								
CLAY								
SAND								
CLAY								
SAND								
						Open Hole		
						From ft. To ft.		
						Screen? ☒ Type stainless Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						6 in. 20 20 ft. 274 ft. 294 ft.		
						Static Water Level		
						80 ft. land surface Measure 09/18/2025		
						Pumping Level (below land surface)		
						89 ft. 4 hrs. Pumping at 68 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer MERRILL Model SMCK612		
						☐ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information		
						Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						high solids bentonite 27 Sacks ft. 266 ft.		
						Nearest Known Source of Contamination		
						500 feet Northwes Direction Septic tank/drain field Type		
						Well disinfected upon completion? ☐ Yes ☐ No		
						Pump ☒ Not Installed Date Installed		
						Manufacturer's name		
						Model Number HP Volt		
						Length of drop pipe ft Capacity g.p. Typ		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock		
						Last Strat		
						Aquifer		
						Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Conroy Well Drilling, Inc. 1987 CONROY, J		
						Licensee Business Lic. or Reg. No. Name of Driller		