

865186

County Stevens

Quad

Quad ID

MINNESOTA DEPARTMENT OF HEALTH

WELL AND BORING REPORT

Minnesota Statutes Chapter 1031

Entry Date05/11/2026

Update Date05/11/2026

Received Date11/03/2025

Well NameTownshipRangeDir SectionSubsection GEISZLER, DON12442W 8null					Well DepthDepth CompletedDate Well Completed 125 ft.125 ft.09/28/2025																																				
ElevationElev. Method					Drill MethodNon-specified RotaryDrill FluidBentonite																																				
Address C/W23569 7 CR MORRIS MN					Use domesticStatusActive																																				
Stratigraphy Information <table><thead><tr><th>Geological Material</th><th>From</th><th>To (ft.)</th><th>Color</th><th>Hardness</th></tr></thead><tbody><tr><td>TOP SOIL</td><td>0</td><td>3</td><td>BLACK</td><td>SOFT</td></tr><tr><td>CLAY</td><td>3</td><td>19</td><td>YELLOW</td><td>SOFT</td></tr><tr><td>CLAY</td><td>19</td><td>75</td><td>GRAY</td><td>MEDIUM</td></tr><tr><td>GRAVEL</td><td>75</td><td>87</td><td>YELLOW</td><td>SOFT</td></tr><tr><td>CLAY</td><td>87</td><td>108</td><td>GRAY</td><td>HARD</td></tr><tr><td>SAND</td><td>108</td><td>125</td><td>GRAY</td><td>SOFT</td></tr></tbody></table>					Geological Material	From	To (ft.)	Color	Hardness	TOP SOIL	0	3	BLACK	SOFT	CLAY	3	19	YELLOW	SOFT	CLAY	19	75	GRAY	MEDIUM	GRAVEL	75	87	YELLOW	SOFT	CLAY	87	108	GRAY	HARD	SAND	108	125	GRAY	SOFT	Well Hydrofractured?YesNoFromTo Well Casing TypeSingle casingJoint Drive Shoe?YesNoAbove/Below	
					Geological Material	From	To (ft.)	Color	Hardness																																
					TOP SOIL	0	3	BLACK	SOFT																																
					CLAY	3	19	YELLOW	SOFT																																
					CLAY	19	75	GRAY	MEDIUM																																
					GRAVEL	75	87	YELLOW	SOFT																																
					CLAY	87	108	GRAY	HARD																																
					SAND	108	125	GRAY	SOFT																																
					Casing DiameterWeightHole Diameter 5 in. To 120 ft. lbs./ft.9 in. To 125 ft.																																				
					Open HoleFromft.Toft.																																				
Screen?TypeMakeJOHNSON DiameterSlot/GauzeLengthSet 5 in. 125 ft. 120 ft. 125 ft.																																									
Static Water Level 77 ft. land surfaceMeasure09/28/2025																																									
Pumping Level (below land surface) 84 ft. 3 hrs. Pumping at40 g.p.m.																																									
Wellhead Completion Pitless adapter manufacturerMERRILLModelSPK Casing Protection12 in. above grade At-grade (Environmental Wells and Borings ONLY)																																									
Grouting InformationWell Grouted?YesNoNot Specified MaterialAmountFromTo high solids bentonite9 Sacksft. 112 ft.																																									
Nearest Known Source of Contamination 70 feetWest DirectionSeptic tank/drain field Type Well disinfected upon completion?YesNo																																									
PumpNot InstalledDate Installed Manufacturer's name Model NumberHPVolt Length of drop pipeftCapacityg.p.Typ																																									
Abandoned Does property have any not in use and not sealed well(s)?YesNo																																									
Variance Was a variance granted from the MDH for this well?YesNo																																									
Miscellaneous First BedrockAquifer Last StratDepth to Bedrockft Located by Locate Method SystemUTM - NAD83, Zone 15, MetersXY Unique Number VerificationInput Date																																									
Angled Drill Hole																																									
Well Contractor Conroy Well Drilling, Inc.1987CONROY, J Licensee BusinessLic. or Reg. No.Name of Driller																																									