

865253

County Goodhue
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 08/01/2023
Update Date 08/01/2023
Received Date 05/06/2023

Well Name WHALEY, JOHN					Township 113	Range 15	Dir W	Section 19	Subsection ACB	Well Depth 440 ft.	Depth Completed 440 ft.	Date Well Completed 01/11/2023			
Elevation					Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Foam				
Address										Use domestic	Status Active				
C/W 356 WESTWOOD HILLS S WELCH MN 55089										Well Hydrofractured? Yes ☐ No ☒		From		To	
Stratigraphy Information										Casing Type		Joint			
Geological Material										Drive Shoe? Yes ☐ No ☒		Above/Below			
CLAY										Casing Diameter 4 in. To		Weight 378 ft. 10.79 lbs./ft.		Hole Diameter 12 in. To 14 ft.	
LIME														8 in. To 378 ft.	
SNADSTONE														4 in. To 440 ft.	
SHALE															
SANDSTONE															
										Open Hole From 378 ft. To 440 ft.					
										Screen? ☐		Type		Make	
Static Water Level															
308 ft. land surface										Measure		01/11/2023			
Pumping Level (below land surface)															
357 ft. 2 hrs. Pumping at										30		g.p.m.			
Wellhead Completion															
Pitless adapter manufacturer BAEKR Model															
☐ Casing Protection ☒ 12 in. above grade															
☐ At-grade (Environmental Wells and Borings ONLY)															
Grouting Information										Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
Material Amount From To															
neat cement 6.5 Cubic yards										ft. 378		ft.			
Nearest Known Source of Contamination															
57 feet North Direction												Sewer Type			
Well disinfected upon completion? ☒ Yes ☐ No															
Pump ☐ Not Installed Date Installed 10/22/2022															
Manufacturer's name SCHAEFER															
Model Number HP 2 Volt 230															
Length of drop pipe 357 ft Capacity 10 g.p. Typ Submersible															
Abandoned															
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No															
Variance															
Was a variance granted from the MDH for this well? ☐ Yes ☒ No															
Miscellaneous															
First Bedrock										Aquifer					
Last Strat										Depth to Bedrock		ft			
Located by															
Locate Method															
System UTM - NAD83, Zone 15, Meters X Y															
Unique Number Verification										Input Date					
Angled Drill Hole															
Well Contractor															
DC Well Drilling, LLC 3920 CARLSON, P															
Licensee Business Lic. or Reg. No. Name of Driller															