

869919

County Houston
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 06/13/2025
Update Date 06/13/2025
Received Date 01/28/2025

Well Name MIERAU, DEAN					Township 104	Range 7	Dir Section W 17	Subsection CCC	Well Depth 163 ft.		Depth Completed 163 ft.		Date Well Completed 05/13/2024	
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Other		
Address C/W 22980 26 CO HOUSTON MN 55943									Use domestic		Status Active			
Stratigraphy Information Geological Material From To (ft.) Color Hardness DRIFT 0 78 BROWN MEDIUM SHALE 78 163 GREEN HARD									Well Hydrofractured? Yes ☐ No ☒		From To			
									Casing Type Single casing		Joint Welded			
									Drive Shoe? Yes ☒ No ☐		Above/Below			
									Casing Diameter 4 in. To 126 ft. 11 lbs./ft.		Hole Diameter 8 in. To 126 ft.			
									8 in. To 79 ft. lbs./ft.		4 in. To 163 ft.			
									Open Hole From 126 ft. To 163 ft.					
									Screen? ☐ Type Make					
									Static Water Level 56 ft. land surface Measure 05/13/2024					
									Pumping Level (below land surface) 61 ft. 2 hrs. Pumping at 15 g.p.m.					
									Wellhead Completion Pitless adapter manufacturer MONITOR Model ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)					
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To neat cement 2 Sacks ft. 126 ft.														
Nearest Known Source of Contamination 55 feet South Direction Septic tank/drain field Type Well disinfected upon completion? ☒ Yes ☐ No														
Pump ☐ Not Installed Date Installed 05/23/2024 Manufacturer's name F&W Model Number HP 1 Volt 10 Length of drop pipe ft Capacity g.p. Typ Submersible														
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No														
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No														
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date														
Angled Drill Hole														
Well Contractor Drussell Well Drilling 1855 DRUSSEL, D. Licensee Business Lic. or Reg. No. Name of Driller														