

871410

County Washington
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 04/10/2024
Received Date 11/13/2023

Well Name PALTRIN LLC	Township 31	Range 20	Dir W	Section 1	Subsection DDA	Well Depth 185 ft.	Depth Completed 185 ft.	Date Well Completed 10/31/2023
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Foam	
Address						Use domestic	Status Active	
Contact 4730 PARK COMMONS DR ST LOUIS PARK MN 55416						Well Hydrofractured? Yes ☐ No ☒ From To		
Well 990 ROSABELLE ST MARINE ON ST CROIX MN						Casing Type Single casing Joint Welded		
Stratigraphy Information						Drive Shoe? Yes ☒ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
SAND/GRAVEL/ROCKS		0	5	BROWN	MEDIUM	4 in. To 147 ft. 10.79 lbs./ft. 12 in. To 13 ft.		
SANDROCK		5	185	VARIED	SFT-HRD	8 in. To 147 ft. 4 in. To 185 ft.		
Open Hole						From 147 ft. To 185 ft.		
Screen? ☐						Type Make		
Static Water Level						96 ft. land surface Measure 10/11/2023		
Pumping Level (below land surface)						136 ft. 2 hrs. Pumping at 35 g.p.m.		
Wellhead Completion						Pitless adapter manufacturer MAASS Model 4J1		
☐ Casing Protection						☒ 12 in. above grade		
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
Material		Amount		From To				
neat cement		48 Sacks		ft. 147 ft.				
Nearest Known Source of Contamination						62 feet East Direction Septic tank/drain field Type		
Well disinfected upon completion?						☒ Yes ☐ No		
Pump ☐ Not Installed						Date Installed 10/31/2023		
Manufacturer's name FLINT + WALLIN								
Model Number 4F10S07301		HP 0.75		Volt 230				
Length of drop pipe 126 ft		Capacity 10 g.p.		Typ Submersible				
Abandoned						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
Variance						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
Miscellaneous						First Bedrock Aquifer		
Last Strat						Depth to Bedrock ft		
Located by								
Locate Method								
System UTM - NAD83, Zone 15, Meters		X		Y				
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor						Mantyla Well Drilling, Inc. 1394 LYON, R.		
Licensee Business						Lic. or Reg. No. Name of Driller		