

871431

County Washington
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/05/2026
Update Date 05/05/2026
Received Date 01/28/2026

Well Name SHERVA, THOR					Township 31	Range 20	Dir W	Section 9	Subsection BBB	Well Depth 120 ft.		Depth Completed 120 ft.		Date Well Completed 12/12/2025													
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid		Other													
Address										Use domestic		Status Active															
Contact 8799 INDIAN BL S COTTAGE GROVE MN 55016										Well Hydrofractured?		Yes ☐ No ☒		From		To											
Well 16915 MAY AV N STILLWATER MN 55082										Casing Type Single casing		Joint Welded															
Stratigraphy Information										Drive Shoe?		Yes ☒ No ☐		Above/Below													
Geological Material					From		To (ft.)		Color		Hardness		Casing Diameter		Weight		Hole Diameter										
DRIFT					0		100		BROWN		SOFT		4 in. To 103 ft. 10.79 lbs./ft.		8 in. To 103 ft.												
LIMEROCK					100		120		BROWN		HARD				4 in. To 120 ft.												
										Open Hole		From 103 ft.		To 120 ft.													
										Screen?		☐		Type		Make											
										Static Water Level		26 ft.		land surface		Measure		12/12/2025									
										Pumping Level (below land surface)																	
										94 ft.		2 hrs.		Pumping at		35		g.p.m.									
										Wellhead Completion																	
										Pitless adapter manufacturer		MAASS		Model		4J1											
										☐ Casing Protection		☒ 12 in. above grade															
										☐ At-grade (Environmental Wells and Borings ONLY)																	
										Grouting Information		Well Grouted?		☒ Yes ☐ No ☐ Not Specified													
										Material		Amount		From		To											
										neat cement		52 Sacks				ft. 103 ft.											
										Nearest Known Source of Contamination																	
										80 feet		South Direction		Septic tank/drain field		Type											
										Well disinfected upon completion?		☒ Yes ☐ No															
										Pump		☐ Not Installed		Date Installed		12/12/2025											
										Manufacturer's name		GRUNDFOS															
										Model Number		10SQE10-		HP 1		Volt 230											
										Length of drop pipe		84 ft		Capacity 10		g.p.		Typ Submersible									
										Abandoned																	
										Does property have any not in use and not sealed well(s)?		☐ Yes ☒ No															
										Variance																	
										Was a variance granted from the MDH for this well?		☐ Yes ☒ No															
										Miscellaneous																	
										First Bedrock				Aquifer													
										Last Strat				Depth to Bedrock				ft									
										Located by																	
										Locate Method																	
										System		UTM - NAD83, Zone 15, Meters		X		Y											
										Unique Number Verification						Input Date											
										Angled Drill Hole																	
										Well Contractor																	
										Mantyla Well Drilling, Inc.		1394		DOFFING, P													
										Licensee Business		Lic. or Reg. No.		Name of Driller													