

871790

County Chisago
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 06/07/2024
Received Date 02/09/2024

Well Name HOME SWEET					Township 33	Range 20	Dir W	Section 24	Subsection AAA
Elevation					Elev. Method				
Address									
Well					26946 QUINLAN AV LINDSTROM MN 55048				
Contact					27587 XYLITE ST NE ISANTI MN 55040				
Stratigraphy Information									
Geological Material		From	To (ft.)	Color	Hardness				
CLAY		0	10						
SAND / GRAVEL		10	28						
CLAY / GRAVEL		28	78						
GRAVEL		78	167						
Well Depth 167 ft.									
Depth Completed 167 ft.									
Date Well Completed 11/07/2023									
Drill Method Non-specified Rotary					Drill Fluid Bentonite				
Use domestic					Status Active				
Well Hydrofractured? Yes ☐ No ☐ From To									
Casing Type Single casing Joint									
Drive Shoe? Yes ☐ No ☐ Above/Below									
Casing Diameter 4 in. To					Weight 157 ft. lbs./ft.			Hole Diameter 8 in. To 50 ft. 6.5 in. To 167 ft.	
Open Hole From ft. To ft.									
Screen? ☒ Type mixed Make									
Diameter		Slot/Gauze		Length		Set			
4 in.		20		10 ft.		157 ft.		167 ft.	
Static Water Level									
90 ft.		land surface				Measure		11/07/2023	
Pumping Level (below land surface)									
130 ft.		1 hrs.		Pumping at		25 g.p.m.			
Wellhead Completion									
Pitless adapter manufacturer					MONITOR			Model SNAPPY	
☐ Casing Protection					☐ 12 in. above grade				
☐ At-grade (Environmental Wells and Borings ONLY)									
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified									
Material		Amount		From		To			
bentonite		5 Sacks				ft. 50 ft.			
Nearest Known Source of Contamination									
50 feet		North Direction				Other Type			
Well disinfected upon completion? ☒ Yes ☐ No									
Pump ☐ Not Installed Date Installed									
Manufacturer's name									
Model Number		HP		Volt					
Length of drop pipe		ft		Capacity		g.p.		Typ	
Abandoned									
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No									
Variance									
Was a variance granted from the MDH for this well? ☐ Yes ☒ No									
Miscellaneous									
First Bedrock					Aquifer				
Last Strat					Depth to Bedrock ft				
Located by									
Locate Method									
System		UTM - NAD83, Zone 15, Meters				X		Y	
Unique Number Verification					Input Date				
Angled Drill Hole									
Well Contractor									
Andy Zuercher Well Drilling					4697		ZUERCHER, A		
Licensee Business					Lic. or Reg. No.		Name of Driller		