

872165

County Sherburne
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 05/29/2024
Received Date 12/22/2023

Well Name FIGGINS, MIKE					Township 34	Range 29	Dir W	Section 4	Subsection DDB	Well Depth 97 ft.		Depth Completed 97 ft.		Date Well Completed 11/27/2023							
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Other									
Address										Use domestic		Status Active									
Contact					7223 100TH AV SE CLEAR LAKE MN 55319																
Well					7236 100TH AV SE CLEAR LAKE MN 55319																
Stratigraphy Information																					
Geological Material		From	To (ft.)	Color	Hardness																
SAND		0	40	BROWN	SOFT																
ROCK		40	41	DK. BRN	M.HARD																
SAND		41	56	BROWN	MEDIUM																
CLAY / SAND / GRAVEL		56	87	DK. RED	MEDIUM																
SAND		87	97	BROWN	MEDIUM																
Open Hole																					
Screen?		☒		Type		stainless		Make		JOHNSON											
Diameter		Slot/Gauze		Length		Set															
2 in.		12		8 ft.		89 ft.		97 ft.													
Static Water Level																					
25 ft.		land surface				Measure				11/27/2023											
Pumping Level (below land surface)																					
95 ft.		1 hrs.		Pumping at				20 g.p.m.													
Wellhead Completion																					
Pitless adapter manufacturer				MONITOR				Model				SNAPPY									
☐		Casing Protection				☒		12 in. above grade													
☐		At-grade (Environmental Wells and Borings ONLY)																			
Grouting Information																					
Well Grouted?				☒		Yes		☐		No		☐		Not Specified							
Material				Amount				From				To									
other				5 Sacks				ft. 50				ft.									
Nearest Known Source of Contamination																					
50 feet		East Direction				Septic tank/drain field				Type											
Well disinfected upon completion?				☒		Yes		☐		No											
Pump																					
☐		Not Installed				Date Installed				11/27/2023											
Manufacturer's name				STA-RITE				HP				0.5		Volt		230					
Model Number				Length of drop pipe				40 ft		Capacity		12 g.p.		Typ		Submersible					
Abandoned																					
Does property have any not in use and not sealed well(s)?														☐		Yes		☒		No	
Variance																					
Was a variance granted from the MDH for this well?														☐		Yes		☒		No	
Miscellaneous																					
First Bedrock				Aquifer																	
Last Strat				Depth to Bedrock								ft									
Located by																					
Locate Method				System				UTM - NAD83, Zone 15, Meters				X		Y							
Unique Number Verification												Input Date									
Angled Drill Hole																					
Well Contractor																					
Fobbe Well, LLP				1919				FOBBE, B													
Licensee Business				Lic. or Reg. No.				Name of Driller													