

872174

County Benton
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 05/23/2024
Received Date 12/22/2023

Well Name SIMONES,					Township 37	Range 31	Dir W	Section 11	Subsection ABA	Well Depth 75 ft.		Depth Completed 75 ft.		Date Well Completed 11/01/2023													
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Other															
Address										Use domestic		Status Active															
Contact 11974 PORTLAND AV BURNSVILLE MN 55337										Well Hydrofractured?		Yes ☐		No ☐		From To											
Well 10255 SUCKER CREEK RD RICE MN 56367										Casing Type Single casing		Joint															
Stratigraphy Information										Drive Shoe?		Yes ☐		No ☐		Above/Below											
Geological Material										Casing Diameter		Weight															
SAND										4 in. To		67 ft.		lbs./ft.													
SAND										25		51		GRAY		SOFT											
CLAY										51		65		GRAY		MEDIUM											
SAND										65		75		BROWN		MEDIUM											
										Open Hole		From		ft.		To		ft.									
										Screen?		☒		Type		stainless		Make		JOHNSON							
										Diameter		Slot/Gauze		Length		Set											
										2 in.		12		8 ft.		67 ft.		75 ft.									
										Static Water Level										3 ft.		land surface		Measure		11/01/2023	
										Pumping Level (below land surface)										73 ft.		1 hrs.		Pumping at		50 g.p.m.	
										Wellhead Completion										Pitless adapter manufacturer		MONITOR		Model		SNAPPY	
										☐ Casing Protection										☒ 12 in. above grade							
										☐ At-grade (Environmental Wells and Borings ONLY)																	
										Grouting Information										Well Grouted?		☒ Yes		☐ No		☐ Not Specified	
Material										Amount		From		To													
other										5 Sacks		ft. 50		ft.													
Nearest Known Source of Contamination										75 feet		North Direction		Septic tank/drain field		Type											
Well disinfected upon completion?										☒ Yes		☐ No															
Pump										☐ Not Installed		Date Installed		11/01/2023													
Manufacturer's name										STA-RITE		HP		0.5		Volt 115											
Length of drop pipe										20 ft		Capacity		10 g.p.		Typ Submersible											
Abandoned										Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																	
Variance										Was a variance granted from the MDH for this well? ☐ Yes ☒ No																	
Miscellaneous										First Bedrock										Aquifer							
Last Strat										Depth to Bedrock										ft							
Located by										Locate Method																	
System										UTM - NAD83, Zone 15, Meters		X		Y													
Unique Number Verification										Input Date																	
Angled Drill Hole																											
Well Contractor										Fobbe Well, LLP										1919		FOBBE, RANDY					
Licensee Business										Lic. or Reg. No.										Name of Driller							