

872181

County Sherburne
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 11/26/2025
Received Date 05/22/2024

Well Name HOMES BY					Township 33	Range 36	Dir Section W 19	Subsection CAD	Well Depth 175 ft.		Depth Completed 175 ft.		Date Well Completed 10/17/2023	
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Other		
Address									Use domestic		Status Active			
Well 14251 201ST AV NW ELK RIVER MN 55330									Well Hydrofractured? Yes ☐ No ☐		From To			
Contact 11692 84TH AV N MAPLE GROVE MN 55369									Casing Type Single casing		Joint			
Stratigraphy Information									Drive Shoe? Yes ☒ No ☐		Above/Below			
Geological Material		From	To (ft.)	Color	Hardness			Casing Diameter 4 in. To 126 ft.		Weight lbs./ft.	Hole Diameter 3.7 in. To 175 ft.			
CLAY/SEAMS SAND		0	74	BROWN	MEDIUM									
SAND		74	91	BROWN	MEDIUM									
CLAY/GRAVEL		91	118	DK. RED	MEDIUM									
SHALE/SANDROCK		118	175	TAN/WHT	MEDIUM									
									Open Hole From ft. To ft.					
									Screen? ☐		Type Make			
									Static Water Level 20 ft. land surface		Measure 10/07/2023			
									Pumping Level (below land surface) 100 ft. 1 hrs. Pumping at		20 g.p.m.			
									Wellhead Completion Pitless adapter manufacturer		MONITOR Model SNAPPY			
									☐ Casing Protection		☒ 12 in. above grade			
									☐ At-grade (Environmental Wells and Borings ONLY)					
									Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
									Material Amount From To					
									other 8 Sacks		ft. 50 ft.			
									Nearest Known Source of Contamination 50 feet Southeast Direction		Septic tank/drain field Type			
									Well disinfected upon completion? ☒ Yes ☐ No					
									Pump ☐ Not Installed Date Installed 10/17/2023					
									Manufacturer's name GRUNDFOS					
									Model Number HP 0.75		Volt 230			
									Length of drop pipe 40 ft Capacity 10 g.p.		Typ Submersible			
									Abandoned Does property have any not in use and not sealed well(s)?		☐ Yes ☒ No			
									Variance Was a variance granted from the MDH for this well?		☐ Yes ☒ No			
									Miscellaneous First Bedrock		Aquifer			
									Last Strat		Depth to Bedrock ft			
									Located by					
									Locate Method					
									System UTM - NAD83, Zone 15, Meters		X Y			
									Unique Number Verification		Input Date			
									Angled Drill Hole					
									Well Contractor Fobbe Well, LLP		1919 FOBBE, B			
									Licensee Business		Lic. or Reg. No. Name of Driller			