

872606

County

Scott

Quad

Veseli

Quad ID

89C

MINNESOTA DEPARTMENT OF HEALTH

WELL AND BORING REPORT

Minnesota Statutes Chapter 1031

Entry Date

01/30/2024

Update Date

02/09/2024

Received Date

11/06/2023

Well Name KING, JIM &					Township 113					Range 22					Dir Section W 28					Subsection DBAACC					Well Depth 192 ft.					Depth Completed 190 ft.					Date Well Completed 09/20/2023				
Elevation 1023					Elev. Method Calc from NED (Natl.Elev.Dataset-30m)					Drill Method Non-specified Rotary					Drill Fluid Water																								
Address C/W 2621 265TH ST E WEBSTER MN 55088																				Use domestic					Status Active														
Well Hydrofractured? Yes No From To																																							
Casing Type Single casing																				Joint Glued																			
Drive Shoe? Yes No Above/Below																																							
Stratigraphy Information Geological Material CLAY CLAY CLAY & SAND SAND										From 0 24 77 174					To (ft.) 24 77 174 192					Color BROWN GRAY GRAY GRAY					Hardness MEDIUM MEDIUM MEDIUM SOFT														
Open Hole From ft. To ft.																																							
Screen? Type plastic Make MONO FLEX																																							
Diameter Slot/Gauze Length Set																																							
4 in. 10 10 ft.																																							
Static Water Level 79 ft. land surface Measure 09/20/2023																																							
Pumping Level (below land surface)																																							
Wellhead Completion Pitless adapter manufacturer MONITOR Model																																							
Casing Protection 12 in. above grade																																							
At-grade (Environmental Wells and Borings ONLY)																																							
Grouting Information Well Grouted? Yes No Not Specified																																							
Material Amount From To																																							
bentonite 2 Sacks ft. 50 ft.																																							
Nearest Known Source of Contamination 80 feet East Direction Well disinfected upon completion? Yes No Sewer Type																																							
Pump Not Installed Date Installed 09/20/2023																																							
Manufacturer's name GOULDS																																							
Model Number 18GS15 HP 1.5 Volt 230																																							
Length of drop pipe 110 ft Capacity 18 g.p. Typ Submersible																																							
Abandoned Does property have any not in use and not sealed well(s)? Yes No																																							
Variance Was a variance granted from the MDH for this well? Yes No																																							
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft																																							
Located by Minnesota Department of Health																																							
Locate Method GPS SA Off (averaged) (15 meters)																																							
System UTM - NAD83, Zone 15, Meters X 462910 Y 4934688																																							
Unique Number Verification Info/GPS from data Input Date 01/30/2024																																							
Angled Drill Hole																																							
Well Contractor Hartmann Well Co., LLP 1622 HARTMANN, B																																							
Licensee Business Lic. or Reg. No. Name of Driller																																							