

873366

County Todd
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 05/28/2025
Received Date 07/22/2024

Well Name UPHOFF, STEVE					Township 128	Range 34	Dir W	Section 28	Subsection DDD	Well Depth 148 ft.		Depth Completed 147 ft.		Date Well Completed 07/12/2024													
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Qwik gel															
Address										Use domestic		Status Active															
Well 19978 96 CR SAUK CENTRE MN										Well Hydrofractured?		Yes ☐		No ☐		From		To									
Contact NEW MUNICH MN										Casing Type Single casing		Joint															
Stratigraphy Information										Drive Shoe?		Yes ☐		No ☐		Above/Below											
Geological Material		From		To (ft.)		Color		Hardness		Casing Diameter		Weight		Hole Diameter													
CLAY		0		64		YELLOW		MEDIUM		5 in. To		139 ft.		lbs./ft.		9 in. To 148 ft.											
CLAY		64		117		BLUE		MEDIUM																			
CLAY		117		131		BLUE		SOFT																			
SAND		131		148		WHITE		SOFT																			
CLAY		148		148		BLUE		MEDIUM																			
										Open Hole		From		ft.		To		ft.									
										Screen? ☒		Type		stainless		Make		JOHNSON									
										Diameter		Slot/Gauze		Length		Set											
										5 in.		20		8 ft.		139 ft.		147 ft.									
										Static Water Level										64 ft.		land surface		Measure		09/19/2023	
										Pumping Level (below land surface)										140 ft.		1 hrs.		Pumping at		40 g.p.m.	
										Wellhead Completion										Pitless adapter manufacturer		BAKER		Model		5X1.25	
										☐ Casing Protection										☐ 12 in. above grade							
										☐ At-grade (Environmental Wells and Borings ONLY)																	
										Grouting Information										Well Grouted?		☒ Yes		☐ No		☐ Not Specified	
Material				Amount				From		To																	
bentonite				8 Sacks						ft. 64		ft.															
Nearest Known Source of Contamination										200 feet		Direction				Type											
Well disinfected upon completion?										☒ Yes		☐ No															
Pump ☐ Not Installed										Date Installed																	
Manufacturer's name										F&W																	
Model Number		10S10		HP		1		Volt		230																	
Length of drop pipe		120 ft		Capacity		g.p.		Typ		Submersible																	
Abandoned										Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																	
Variance										Was a variance granted from the MDH for this well? ☐ Yes ☒ No																	
Miscellaneous										First Bedrock										Aquifer							
Last Strat										Depth to Bedrock										ft							
Located by																											
Locate Method																											
System		UTM - NAD83, Zone 15, Meters		X		Y																					
Unique Number Verification										Input Date																	
Angled Drill Hole																											
Well Contractor										Wheels Enterprise Inc.										3214		WIELING, J					
Licensee Business										Lic. or Reg. No.										Name of Driller							