

874360

County Meeker
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 01/12/2026
Received Date 09/22/2025

Well Name CASSENS,	Township 118	Range 29	Dir W	Section 27	Subsection CBA	Well Depth 196 ft.	Depth Completed 196 ft.	Date Well Completed 09/09/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid	Other
Address						Use domestic	Status Active	
Contact 15813 200TH ST HUTCHINSON MN 55350						Well Hydrofractured? Yes ☐ No ☐ From To		
Well 17391 721ST AV DASSEL MN 55325						Casing Type Single casing Joint Glued		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
TOPSOIL		0	1	BLACK	SOFT	4 in. To 191 ft. lbs./ft. 6.7 in. To 196 ft.		
CLAY+WHUTESAND		1	68	DK. GRY	SOFT			
CLAY		68	160	GRAY	MEDIUM			
CLAY		160	182	GRAY	SOFT			
SAND		182	196	GREEN	SOFT			
Open Hole						From	ft.	To ft.
Screen? ☒						Type other	Make	BIGFOOT
Diameter						Slot/Gauze	Length	Set
3 in.						0	5 ft.	191 ft. 196 ft.
Static Water Level								
8 ft.						land surface	Measure	08/02/2024
Pumping Level (below land surface)								
20 ft.						1.5 hrs.	Pumping at	35 g.p.m.
Wellhead Completion								
Pitless adapter manufacturer						MERRILL	Model	MS MCK414
☐ Casing Protection						☐ 12 in. above grade		
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
Material						Amount	From	To
other						5 Sacks	ft.	75 ft.
Nearest Known Source of Contamination								
40 feet						East Direction	Body of water	Type
Well disinfected upon completion?						☒ Yes ☐ No		
Pump ☐ Not Installed						Date Installed	08/02/2024	
Manufacturer's name						GRUNDFOS		
Model Number						10SQE07-	HP	0.75 Volt 230
Length of drop pipe						42 ft	Capacity	10 g.p. Typ Submersible
Abandoned								
Does property have any not in use and not sealed well(s)?						☐ Yes ☒ No		
Variance								
Was a variance granted from the MDH for this well?						☐ Yes ☒ No		
Miscellaneous								
First Bedrock						Aquifer		
Last Strat						Depth to Bedrock	ft	
Located by								
Locate Method								
System						UTM - NAD83, Zone 15, Meters	X	Y
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor								
Mathews Drilling and Pump						1845	MATHEWS, R	
Licensee Business						Lic. or Reg. No.	Name of Driller	