

874428

County Wright
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 02/16/2024
Received Date 10/12/2023

Well Name DINGMAN					Township 121	Range 28	Dir W	Section 33	Subsection DBD	Well Depth 68 ft.		Depth Completed 68 ft.		Date Well Completed 09/22/2023			
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Bentonite					
Address										Use domestic		Status Active					
Contact 9010 90TH LA GREENFIELD MN 55373																	
Well 6247 PILGER AV NW ANNANDALE MN																	
Stratigraphy Information										Well Hydrofractured? Yes ☐ No ☐		From To					
Geological Material					From	To (ft.)	Color	Hardness			Casing Type Single casing		Joint				
ROCKS/CLAY					0	8					Drive Shoe? Yes ☐ No ☐		Above/Below				
CLAY					8	17					Casing Diameter 4 in. To 60 ft.		Weight lbs./ft.		Hole Diameter 7 in. To 68 ft.		
ROCKS/GRAVEL					17	24											
CLAY					24	57											
SAND					57	68											
										Open Hole		From	ft.	To	ft.		
										Screen? ☒		Type stainless		Make JOHNSON			
										Diameter 2 in.		Slot/Gauze 15		Length 8 ft.		Set 60 ft. 68 ft.	
										Static Water Level							
										18 ft.		land surface		Measure		09/22/2023	
										Pumping Level (below land surface)							
										65 ft.		1.5 hrs.		Pumping at		30 g.p.m.	
										Wellhead Completion							
										Pitless adapter manufacturer		BAKER		Model		BULLDOG	
										☐ Casing Protection		☒ 12 in. above grade					
										☐ At-grade (Environmental Wells and Borings ONLY)							
										Grouting Information		Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
										Material bentonite		Amount 5 Sacks		From ft.		To 50 ft.	
										Nearest Known Source of Contamination							
										38 feet		East Direction		Body of water		Type	
										Well disinfected upon completion?		☒ Yes ☐ No					
										Pump ☐ Not Installed		Date Installed		09/22/2023			
										Manufacturer's name		GOULDS					
										Model Number		VFD		HP		0.75	
										Length of drop pipe		40 ft		Capacity		10 g.p.	
														Typ		Submersible	
										Abandoned							
										Does property have any not in use and not sealed well(s)?						☐ Yes ☒ No	
										Variance							
										Was a variance granted from the MDH for this well?						☐ Yes ☒ No	
										Miscellaneous							
										First Bedrock		Aquifer					
										Last Strat		Depth to Bedrock		ft			
										Located by							
										Locate Method							
										System		UTM - NAD83, Zone 15, Meters		X		Y	
										Unique Number Verification						Input Date	
										Angled Drill Hole							
										Well Contractor							
										Driven Drilling, LLC		3346		MOTZKO, JASON			
										Licensee Business		Lic. or Reg. No.		Name of Driller			