

874519

County Cass
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 02/09/2026
Received Date 11/03/2025

Well Name SMITH, ALLYN & 140	Township 29	Range W 30	Dir Section ADC	Subsection															
Elevation	Elev. Method																		
Address Well 1931 30TH ST NW HACKENSACK MN 56452 Contact 5784 EVERGREEN LA SHOREVIEW MN 55126																			
Stratigraphy Information <table><tr><td>Geological Material</td><td>From</td><td>To (ft.)</td><td>Color</td><td>Hardness</td></tr><tr><td>CLAY</td><td>0</td><td>14</td><td>BROWN</td><td>HARD</td></tr><tr><td>SAND</td><td>14</td><td>51</td><td>BROWN</td><td>SOFT</td></tr></table>					Geological Material	From	To (ft.)	Color	Hardness	CLAY	0	14	BROWN	HARD	SAND	14	51	BROWN	SOFT
Geological Material	From	To (ft.)	Color	Hardness															
CLAY	0	14	BROWN	HARD															
SAND	14	51	BROWN	SOFT															
Well Depth 51 ft.		Depth Completed 51 ft.		Date Well Completed 12/26/2025															
Drill Method Non-specified Rotary		Drill Fluid Bentonite																	
Use domestic				Status Active															
Well Hydrofractured?		Yes ☐	No ☒	From To															
Casing Type Single casing		Joint																	
Drive Shoe?		Yes ☐	No ☒	Above/Below															
Casing Diameter 4 in. To 46 ft.		Weight lbs./ft.		Hole Diameter 7.9 in. To 51 ft.															
Open Hole <table><tr><td>From</td><td>ft.</td><td>To</td><td>ft.</td></tr></table>					From	ft.	To	ft.											
From	ft.	To	ft.																
Screen? ☒ Type stainless Make JOHNSON																			
Diameter 2 in.		Slot/Gauze 10	Length 5 ft.	Set 46 ft. 51 ft.															
Static Water Level 21 ft. land surface Measure 12/26/2025																			
Pumping Level (below land surface) ft. hrs. Pumping at 20 g.p.m.																			
Wellhead Completion Pitless adapter manufacturer MONITOR Model SNAPPY ☐ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)																			
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified																			
Material bentonite		Amount 4 Sacks	From ft. 43	To ft.															
Nearest Known Source of Contamination 50 feet Southwes Direction Sewer Type																			
Well disinfected upon completion? ☒ Yes ☐ No																			
Pump ☐ Not Installed Date Installed 12/29/2024																			
Manufacturer's name STA-RITE																			
Model Number		HP 0.5	Volt 230																
Length of drop pipe		ft	Capacity 10	g.p. Typ Submersible															
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																			
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No																			
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date																			
Angled Drill Hole																			
Well Contractor Area Lakes Well Drilling 2107 FREEMAN, L. Licensee Business Lic. or Reg. No. Name of Driller																			