

876176

County Olmsted
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 06/30/2023
Update Date 06/26/2025
Received Date 01/30/2023

Well Name GROTEBOER,	Township 106	Range 14	Dir W	Section 21	Subsection BCD
Elevation	Elev. Method				
Address					
Well 3279 BAMBER HILLS LA SW ROCHESTER MN 55902					
Contact 2518 FOX VALLEY DR SW ROCHESTER MN 55902					
Stratigraphy Information					
Geological Material	From	To (ft.)	Color	Hardness	
DRIFT	0	25	TAN	SOFT	
LIMESTONE	25	105	TAN	HARD	
SHALE	105	165	TAN	SOFT	
LIMESTONE	165	195	GRAY	HARD	
SANDSTONE	195	275	TAN	SOFT	
LIMESTONE	275	330	TAN	HARD	
LIMESTONE	330	390	TAN	SOFT	
LIMESTONE	390	410	TAN	HARD	
LIMESTONE	410	459	GRAY	HARD	
Well Depth 459 ft.					
Depth Completed 459 ft.					
Date Well Completed 11/22/2022					
Drill Method Non-specified Rotary					
Drill Fluid Foam					
Use domestic					
Status Active					
Well Hydrofractured? Yes ☐ No ☒ From To					
Casing Type Step down					
Joint Welded					
Drive Shoe? Yes ☒ No ☐ Above/Below					
Casing Diameter Weight Hole Diameter					
4 in. To 413 ft. lbs./ft. 12 in. To 30 ft.					
8 in. To 30 ft. lbs./ft. 8 in. To 413 ft.					
4 in. To 459 ft.					
Open Hole From 413 ft. To 459 ft.					
Screen? ☐ Type Make					
Static Water Level					
200 ft. land surface Measure 11/03/2022					
Pumping Level (below land surface)					
210 ft. 2 hrs. Pumping at 15 g.p.m.					
Wellhead Completion					
Pitless adapter manufacturer BAKER Model 4X5					
☐ Casing Protection ☐ 12 in. above grade					
☐ At-grade (Environmental Wells and Borings ONLY)					
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
Material Amount From To					
pearock 4.5 Cubic yards 275 ft. 413 ft.					
neat cement 4.75 Cubic yards ft. 413 ft.					
neat cement 0.25 Cubic yards ft. 30 ft.					
Nearest Known Source of Contamination					
50 feet Direction Type					
Well disinfected upon completion? ☒ Yes ☐ No					
Pump ☐ Not Installed Date Installed 11/18/2022					
Manufacturer's name GRUNDFOS					
Model Number 25S3015 HP 3 Volt 230					
Length of drop pipe 231 ft Capacity 25 g.p. Typ Submersible					
Abandoned					
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No					
Variance					
Was a variance granted from the MDH for this well? ☐ Yes ☒ No					
Miscellaneous					
First Bedrock Aquifer					
Last Strat Depth to Bedrock ft					
Located by					
Locate Method					
System UTM - NAD83, Zone 15, Meters X Y					
Unique Number Verification Input Date					
Angled Drill Hole					
Well Contractor					
Thein Well Rochester, Inc. 2641 STROBEL, D					
Licensee Business Lic. or Reg. No. Name of Driller					
Remarks					
Minnesota Well Index Report					
876176					
Printed on 08/13/2026 HE-01205-15					