

876788

County Anoka
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 06/28/2023
Received Date 08/17/2022

Well Name NIH HOMES					Township 33	Range 25	Dir W	Section 25	Subsection BAA
Elevation					Elev. Method				
Address									
Well 5390 192ND CI NW NOWTHEN MN 55330									
Contact 6840 213TH AV NW ELK RIVER MN 55330									
Stratigraphy Information									
Geological Material		From	To (ft.)	Color	Hardness				
SAND		0	10	BROWN	SOFT				
CLAY		10	20	BROWN	SFT-MED				
CLAY GRAVEL ROCK		20	125	BRN/BLK	MED-HRD				
CLAY & SAND		125	132	BROWN	MED-HRD				
SHALE SANDROCK		132	200	GRN/WHT	HARD				
Well Depth 200 ft.									
Depth Completed 200 ft.									
Date Well Completed 07/21/2022									
Drill Method Non-specified Rotary					Drill Fluid Qwik gel				
Use domestic					Status Active				
Well Hydrofractured? Yes ☐ No ☒ From To									
Casing Type Single casing					Joint Threaded				
Drive Shoe? Yes ☒ No ☐					Above/Below				
Casing Diameter 4 in. To 135 ft. 11 lbs./ft.					Hole Diameter 6.5 in. To 136 ft.				
Open Hole From 136 ft. To 200 ft.									
Screen? ☐ Type Make									
Static Water Level 30 ft. land surface Measure 07/21/2022									
Pumping Level (below land surface) 136 ft. 2 hrs. Pumping at 50 g.p.m.									
Wellhead Completion Pitless adapter manufacturer MERRILL Model MCK7 ☒ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)									
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To cuttings 50 ft. 136 ft. well grouted, type unknown 3 Sacks ft. 50 ft.									
Nearest Known Source of Contamination 50 feet East Direction Septic tank/drain field Type Well disinfected upon completion? ☒ Yes ☐ No									
Pump ☐ Not Installed Date Installed 07/25/2022 Manufacturer's name FLOWISE Model Number P18S10 HP 1 Volt 230 Length of drop pipe 60.1 ft Capacity 18 g.p. Typ Submersible									
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No									
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No									
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date									
Angled Drill Hole									
Well Contractor McAlpines Well Drilling of 1477 MCALPINE Licensee Business Lic. or Reg. No. Name of Driller									