

877616

County Hubbard
Quad Skunk Lake
Quad ID 279D

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 04/03/2023
Received Date 07/14/2022

Well Name EDEVOLD,	Township 141	Range 35	Dir W	Section 24	Subsection BBBACB	Well Depth 65 ft.	Depth Completed 65 ft.	Date Well Completed 06/28/2022
Elevation 1486	Elev. Method Calc from NED (Natl.Elev.Dataset-30m)				Drill Method Non-specified Rotary	Drill Fluid Bentonite		
Address						Use domestic	Status Active	
Contact 17391 40 CR PARK RAPIDS MN 56470						Well Hydrofractured? Yes ☐ No ☒ From To		
Well 14589 40 CR PARK RAPIDS MN 56470						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter 4 in. To 55 ft. 1 lbs./ft.		
TOP SOIL		0	1	BLACK	SOFT	Hole Diameter 6.7 in. To 65 ft.		
CLAY		1	34	YELLOW	SOFT			
SAND		34	65	GRAY	SOFT			
Open Hole						From	ft.	To ft.
Screen? ☒						Type plastic	Make JOHNSON BRADY	
Diameter						Slot/Gauze	Length	Set
4 in.						12	10 ft.	55 ft. 65 ft.
Static Water Level								
31 ft.						land surface	Measure	06/13/2022
Pumping Level (below land surface)								
54 ft.						1 hrs.	Pumping at	50 g.p.m.
Wellhead Completion								
Pitless adapter manufacturer						SNAPPY	Model	MONITOR
☐ Casing Protection						☒ 12 in. above grade		
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted?	☒ Yes	☐ No ☐ Not Specified
Material						Amount	From	To
high solids bentonite						7 Sacks	ft.	50 ft.
Nearest Known Source of Contamination								
feet						Direction	Type	
Well disinfected upon completion?						☒ Yes	☐ No	
Pump ☐ Not Installed						Date Installed	06/28/2022	
Manufacturer's name						PENTEK		
Model Number						HP	Volt	
4JP07221						0.75	230	
Length of drop pipe						ft	Capacity	g.p. Typ Submersible
40						10		
Abandoned								
Does property have any not in use and not sealed well(s)?						☐ Yes	☒ No	
Variance								
Was a variance granted from the MDH for this well?						☐ Yes	☒ No	
Miscellaneous								
First Bedrock						Aquifer		
Last Strat						Depth to Bedrock	ft	
Located by						Minnesota Department of Health		
Locate Method						GPS SA Off (averaged) (15 meters)		
System						UTM - NAD83, Zone 15, Meters	X 343114	Y 5209633
Unique Number Verification						Info/GPS from data	Input Date	04/03/2023
Angled Drill Hole								
Well Contractor								
Elsner Well Drilling, Inc.						1374	S MONROE	
Licensee Business						Lic. or Reg. No.	Name of Driller	