

877660

County Chisago
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 02/03/2026
Received Date 01/07/2026

Well Name SHARSHNAS,	Township 33	Range 20	Dir W	Section 14	Subsection BBD	Well Depth 111 ft.	Depth Completed 111 ft.	Date Well Completed 11/13/2025
Elevation	Elev. Method					Drill Method Cable Tool	Drill Fluid	
Address						Use domestic	Status Active	
Well 14451 CHISAGO BL LINDSTROM MN 55045						Well Hydrofractured? Yes ☐ No ☐ From To		
Contact 28275 OLINDA TR LINDSTROM MN 55045						Casing Type Single casing Joint Threaded		
Stratigraphy Information						Drive Shoe? Yes ☒ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight		
TOPSOIL		0	1	BLACK	SOFT	4 in. To 106 ft. 11 lbs./ft.		
CLAY		1	22	BROWN	SOFT			
SANDY CLAY		22	34	BROWN	SOFT			
ROCKY BOULDER		34	35		HARD			
GRAVEL CLAY		35	44	BROWN	MEDIUM			
GRAVEL CLAY ROCKS		44	88	VARIED	MEDIUM			
SAND/GRAVEL+ROCK		88	111		MEDIUM			
Open Hole						From	ft.	To ft.
Screen? ☒						Type stainless	Make JOHNSON	
Diameter		Slot/Gauze		Length		Set		
2 in.		15		8 ft.		103 ft. 111 ft.		
Static Water Level								
69 ft.		land surface				Measure		11/27/2025
Pumping Level (below land surface)								
100 ft.		2 hrs.		Pumping at		20		g.p.m.
Wellhead Completion								
Pitless adapter manufacturer		BAKER		Model		SNAPPY		
☒ Casing Protection		☒ 12 in. above grade						
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted?	☒ Yes	☐ No ☐ Not Specified
Material		Amount		From		To		
bentonite						ft. 106 ft.		
Nearest Known Source of Contamination								
60 feet		Northeas Direction				Sewer Type		
Well disinfected upon completion?						☒ Yes	☐ No	
Pump ☐ Not Installed						Date Installed	11/27/2025	
Manufacturer's name						STARITE		
Model Number		S10P4HS07		HP		0.75		Volt 230
Length of drop pipe		80 ft		Capacity		12		g.p. Typ Submersible
Abandoned								
Does property have any not in use and not sealed well(s)?						☐ Yes		☒ No
Variance								
Was a variance granted from the MDH for this well?						☐ Yes		☒ No
Miscellaneous								
First Bedrock				Aquifer				
Last Strat				Depth to Bedrock		ft		
Located by								
Locate Method								
System		UTM - NAD83, Zone 15, Meters		X		Y		
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor								
Rivers Edge Plumbing and		3528		ANDERSON, M				
Licensee Business		Lic. or Reg. No.		Name of Driller				