

877896

County Douglas
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/20/2023
Update Date 04/20/2023
Received Date 17/10/2022

Well Name KLIMEK,					Township 128	Range 38	Dir W	Section 19	Subsection CBA	Well Depth 104 ft.			Depth Completed 104 ft.			Date Well Completed 09/27/2022		
Elevation					Elev. Method					Drill Method Non-specified Rotary			Drill Fluid Qwik gel					
Address										Use domestic			Status Active					
C/W 8654 HUNTERS BAY RD SW ALEXANDRIA MN										Well Hydrofractured? Yes ☐ No ☐			From To					
Well 4700 JACK RABBIT TR NW ALEXANDRIA MN 56308										Casing Type Single casing			Joint					
Stratigraphy Information										Drive Shoe? Yes ☐ No ☒			Above/Below					
Geological Material					From	To (ft.)	Color	Hardness		Casing Diameter			Weight	Hole Diameter				
SAND					0	11	BROWN	SOFT		4 in. To 94 ft.			lbs./ft.	8 in. To 106 ft.				
CLAY					11	21	BROWN	MEDIUM										
SAND					21	43	BROWN	SOFT										
CLAY					43	78	BLUE	MEDIUM										
FINE SAND					78	104	GRAY	SOFT										
CLAY					104	106	BLUE	MEDIUM										
										Open Hole			From	ft.	To	ft.		
										Screen? ☒			Type telescoping		Make JOHNSON			
										Diameter		Slot/Gauze		Length		Set		
										3 in.		7		10 ft.		94 ft. 104 ft.		
										Static Water Level								
										9 ft.		land surface		Measure		09/27/2022		
										Pumping Level (below land surface)								
										104 ft.		2 hrs.		Pumping at		80 g.p.m.		
										Wellhead Completion								
										Pitless adapter manufacturer			Model					
										☐ Casing Protection			☒ 12 in. above grade					
										☐ At-grade (Environmental Wells and Borings ONLY)								
										Grouting Information			Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
										Material		Amount		From		To		
										cuttings				55 ft.		90 ft.		
										other				90 ft.		104 ft.		
										bentonite				ft. 55		ft.		
										Nearest Known Source of Contamination								
										40 feet		South Direction		Sewer Type				
										Well disinfected upon completion? ☒ Yes ☐ No								
										Pump ☒ Not Installed			Date Installed					
										Manufacturer's name								
										Model Number		HP		Volt				
										Length of drop pipe		ft Capacity		g.p. Typ				
										Abandoned								
										Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No								
										Variance								
										Was a variance granted from the MDH for this well? ☐ Yes ☒ No								
										Miscellaneous								
										First Bedrock		Aquifer						
										Last Strat		Depth to Bedrock		ft				
										Located by								
										Locate Method								
										System		UTM - NAD83, Zone 15, Meters		X Y				
										Unique Number Verification		Input Date						
										Angled Drill Hole								
										Well Contractor								
										Darin Weisel Well Service		1359		WEISEL,D				
										Licensee Business		Lic. or Reg. No.		Name of Driller				
Remarks GROUTING INFO- MATERIAL3 = G-PACK																		