

878971

County Stearns
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 05/05/2026
Received Date 02/02/2026

Well Name NIELSEN,					Township 125		Range 32		Dir Section W 25		Subsection DAB		Well Depth 50 ft.			Depth Completed 50 ft.			Date Well Completed 12/15/2025		
Elevation					Elev. Method					Drill Method Non-specified Rotary			Drill Fluid Bentonite								
Address												Use domestic			Status Active						
C/W 25633 334TH ST ALBANY MN 56307												Well Hydrofractured? Yes ☐ No ☐			From To						
Stratigraphy Information												Casing Type Single casing			Joint						
Geological Material												Drive Shoe? Yes ☐ No ☐			Above/Below						
CLAY												Casing Diameter 5 in. To 46 ft.			Weight lbs./ft.			Hole Diameter 8.7 in. To 50 ft.			
SAND																					
CLAY																					
SAND																					
												Open Hole			From ft. To ft.						
												Screen? ☒			Type plastic			Make			
												Diameter Slot/Gauze Length Set									
												4 in. 20 4 ft. 46 ft. 50 ft.									
												Static Water Level									
												15 ft. land surface Measure 12/15/2025									
												Pumping Level (below land surface)									
												20 ft. 2 hrs. Pumping at 20 g.p.m.									
												Wellhead Completion									
												Pitless adapter manufacturer Model									
												☐ Casing Protection ☐ 12 in. above grade									
												☐ At-grade (Environmental Wells and Borings ONLY)									
												Grouting Information			Well Grouted? ☒ Yes ☐ No ☐ Not Specified						
												Material Amount From To									
												other ft. 36 ft.									
												Nearest Known Source of Contamination									
												75 feet East Direction Septic tank/drain field Type									
												Well disinfected upon completion? ☒ Yes ☐ No									
												Pump ☐ Not Installed Date Installed									
												Manufacturer's name									
												Model Number HP Volt									
												Length of drop pipe ft Capacity g.p. Typ									
												Abandoned									
												Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No									
												Variance									
												Was a variance granted from the MDH for this well? ☐ Yes ☒ No									
												Miscellaneous									
												First Bedrock Aquifer									
												Last Strat Depth to Bedrock ft									
												Located by									
												Locate Method									
												System UTM - NAD83, Zone 15, Meters X Y									
												Unique Number Verification Input Date									
												Angled Drill Hole									
												Well Contractor									
												Albany Wells, Inc. 1650 ATKINSON, T.									
												Licensee Business Lic. or Reg. No. Name of Driller									