

879333

County St. Louis
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/06/2026
Update Date 04/06/2026
Received Date 12/22/2025

Well Name PRITCHARD,					Township 60	Range 21	Dir W	Section 30	Subsection ACC	Well Depth 44 ft.		Depth Completed 42 ft.		Date Well Completed 08/15/2025									
Elevation					Elev. Method					Drill Method Multiple methods used		Drill Fluid											
Address										Use domestic		Status Active											
Contact 425 42ND ST HIBBING MN										Well Hydrofractured? Yes ☐ No ☒		From		To									
Well 12993 STURGEON RD MN										Casing Type Single casing		Joint											
Stratigraphy Information										Drive Shoe? Yes ☐ No ☐		Above/Below											
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter		Weight		Hole Diameter													
LOAM		0	4	TAN	SOFT	6 in. To		42 ft.		lbs./ft.		6 in. To		42 ft.									
CLAY		4	18	TAN	SOFT																		
ROCKS		18	20	VARIED	HARD																		
CLAY ROCKS		20	40	TAN	MEDIUM																		
BROKEN ROCK/ SAND		40	44	BROWN	MEDIUM																		
										Open Hole		From		ft.		To		ft.					
										Screen?		☐		Type				Make					
Static Water Level										4 ft.		land surface		Measure		08/15/2025							
Pumping Level (below land surface)										ft.		hrs.		Pumping at		10 g.p.m.							
Wellhead Completion										Pitless adapter manufacturer		SNAPPY		Model		4C-1							
										☐ Casing Protection		☒ 12 in. above grade											
										☐ At-grade (Environmental Wells and Borings ONLY)													
Grouting Information										Well Grouted?		☒ Yes ☐ No ☐ Not Specified											
Material		Amount		From		To																	
bentonite		2 Sacks				ft.		ft.															
Nearest Known Source of Contamination										75 feet		Northwes Direction		Tanks Type									
Well disinfected upon completion?										☐ Yes ☒ No													
Pump										☐ Not Installed		Date Installed											
Manufacturer's name										A FLOWISE													
Model Number										HP		0.5		Volt		230							
Length of drop pipe										20 ft		Capacity		10 g.p.		Typ							
Abandoned										Does property have any not in use and not sealed well(s)?		☐ Yes ☒ No											
Variance										Was a variance granted from the MDH for this well?		☐ Yes ☒ No											
Miscellaneous										First Bedrock		Aquifer											
Last Strat										Depth to Bedrock				ft									
Located by																							
Locate Method																							
System										UTM - NAD83, Zone 15, Meters		X		Y									
Unique Number Verification														Input Date									
Angled Drill Hole																							
Well Contractor										Marks Well and Pump		1675		SWADER, M									
Licensee Business										Lic. or Reg. No.				Name of Driller									
Minnesota Well Index Report					879333					Printed on 10/02/2026 HE-01205-15													