

879418

County Anoka
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 10/30/2025
Received Date 07/29/2024

Well Name SEBURG, MARK					Township 33	Range 23	Dir Section W 35	Subsection BAA	Well Depth 174 ft.		Depth Completed 174 ft.		Date Well Completed 06/21/2024																								
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Bentonite																									
Address C/W 3734 EDMER LA NE EAST BETHEL MN 55092									Use domestic		Status Active																										
Stratigraphy Information <table><tr><td>Geological Material</td><td>From</td><td>To (ft.)</td><td>Color</td><td>Hardness</td></tr><tr><td>SAND</td><td>0</td><td>82</td><td>BROWN</td><td>SOFT</td></tr><tr><td>CLAY, GRAVEL</td><td>82</td><td>103</td><td>BROWN</td><td>MEDIUM</td></tr><tr><td>SAND, GRAVEL</td><td>103</td><td>126</td><td>BROWN</td><td>MEDIUM</td></tr><tr><td>SANDROCK</td><td>126</td><td>174</td><td>BROWN</td><td>HARD</td></tr></table>									Geological Material	From	To (ft.)	Color	Hardness	SAND	0	82	BROWN	SOFT	CLAY, GRAVEL	82	103	BROWN	MEDIUM	SAND, GRAVEL	103	126	BROWN	MEDIUM	SANDROCK	126	174	BROWN	HARD	Well Hydrofractured? Yes ☐ No ☒ From		To	
									Geological Material	From	To (ft.)	Color	Hardness																								
									SAND	0	82	BROWN	SOFT																								
									CLAY, GRAVEL	82	103	BROWN	MEDIUM																								
									SAND, GRAVEL	103	126	BROWN	MEDIUM																								
									SANDROCK	126	174	BROWN	HARD																								
									Casing Type Single casing		Joint Threaded																										
									Drive Shoe? Yes ☒ No ☐		Above/Below																										
									Casing Diameter 4 in. To		Weight 135 ft. lbs./ft.		Hole Diameter 8.5 in. To 50 ft.																								
													6.5 in. To 135 ft.																								
				3.8 in. To 174 ft.																																	
Open Hole From 135 ft. To 174 ft.																																					
Screen? ☐		Type		Make																																	
Static Water Level 4 ft. land surface Measure 06/21/2024																																					
Pumping Level (below land surface) 60 ft. 3 hrs. Pumping at 60 g.p.m.																																					
Wellhead Completion Pitless adapter manufacturer AQUASEAL Model 4X1 ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)																																					
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite 4 Sacks ft. 50 ft.																																					
Nearest Known Source of Contamination 38 feet North Direction Body of water Type Well disinfected upon completion? ☒ Yes ☐ No																																					
Pump ☐ Not Installed Date Installed 07/02/2024 Manufacturer's name FLOWISE Model Number P10S05 HP 0.5 Volt 115 Length of drop pipe 40 ft Capacity g.p. Typ Submersible																																					
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☐ No																																					
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No																																					
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date																																					
Angled Drill Hole																																					
Well Contractor Mork Well Co., Inc. 1877 TORGERSON, R Licensee Business Lic. or Reg. No. Name of Driller																																					