

879573

County Mille Lacs
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 05/23/2024
Received Date 12/22/2023

Well Name AMERIBUILT					Township 36	Range 26	Dir W	Section 34	Subsection ADD	Well Depth 60 ft.		Depth Completed 60 ft.		Date Well Completed 10/12/2023			
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Bentonite					
Address										Use domestic				Status Active			
Well 7149 ASPEN RD PRINCETON MN 55371										Well Hydrofractured?		Yes ☐ No ☒		From		To	
Contact 904 W. DIVISION ST WAITE PARK MN 56387										Casing Type Single casing				Joint			
Stratigraphy Information										Drive Shoe?		Yes ☐ No ☒		Above/Below			
Geological Material		From		To (ft.)		Color		Hardness		Casing Diameter		Weight		Hole Diameter			
SANDY CLAY		0		32		BROWN		MEDIUM		4 in. To 50 ft. 2.25 lbs./ft.				7.8 in. To 60 ft.			
SAND		32		50		BROWN		SOFT									
AQUIFER		50		60		BROWN		SOFT									
										Open Hole		From ft.		To ft.			
										Screen? ☒		Type plastic		Make JET STREAM			
										Diameter		Slot/Gauze Length		Set			
										4 in. 10		10 ft.		50 ft. 60 ft.			
										Static Water Level							
										23 ft. land surface				Measure		10/12/2023	
										Pumping Level (below land surface)							
										40 ft. 1 hrs. Pumping at				30 g.p.m.			
										Wellhead Completion							
										Pitless adapter manufacturer				Model			
										☐ Casing Protection		☐ 12 in. above grade					
										☐ At-grade (Environmental Wells and Borings ONLY)							
										Grouting Information		Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
										Material		Amount		From		To	
										bentonite		6 Sacks				ft. 50 ft.	
										Nearest Known Source of Contamination							
										feet		Direction				Type	
										Well disinfected upon completion? ☒ Yes ☐ No							
										Pump ☒ Not Installed		Date Installed					
										Manufacturer's name							
										Model Number		HP		Volt			
										Length of drop pipe		ft Capacity		g.p. Typ			
										Abandoned							
										Does property have any not in use and not sealed well(s)?		☐ Yes ☒ No					
										Variance							
										Was a variance granted from the MDH for this well?		☐ Yes ☒ No					
										Miscellaneous							
										First Bedrock				Aquifer			
										Last Strat				Depth to Bedrock		ft	
										Located by							
										Locate Method							
										System		UTM - NAD83, Zone 15, Meters		X		Y	
										Unique Number Verification				Input Date			
										Angled Drill Hole							
										Well Contractor							
										Bills Well Drilling, Inc.		2123		GRAHAM, KELLY			
										Licensee Business		Lic. or Reg. No.		Name of Driller			