

879580

County Anoka
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 06/03/2024
Received Date 01/25/2024

Well Name FLECK, NOVAK					Township 34	Range 22	Dir W	Section 36	Subsection DBD	Well Depth 90 ft.			Depth Completed 90 ft.			Date Well Completed 11/14/2023			
Elevation					Elev. Method					Drill Method Non-specified Rotary			Drill Fluid Bentonite						
Address										Use domestic			Status Active						
Well 8910 RYAN LAKE DR NE STACY MN 55079										Well Hydrofractured? Yes ☐ No ☒			From To						
Contact 8857 ZEALAND AV N BROOKLYN PARK MN 55445										Casing Type Single casing			Joint						
Stratigraphy Information										Drive Shoe? Yes ☐ No ☐			Above/Below						
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter			Weight			Hole Diameter							
SAND		0	6	BROWN	SOFT	4 in. To 80 ft.			2.25 lbs./ft.			7.8 in. To 90 ft.							
CLAY		6	26	GRAY	MEDIUM	0 in. To ft.			lbs./ft.										
SAND		26	55	BROWN	SOFT	0 in. To ft.			lbs./ft.										
CLAY		55	80	GRAY	MEDIUM														
AQUIFER		80	90	BROWN	SOFT														
Open Hole										From	ft.	To	ft.						
Screen? ☒										Type plastic		Make JET STREAM							
Diameter										Slot/Gauze		Length		Set					
4 in.										10		10 ft.		80 ft.		90 ft.			
Static Water Level										20 ft.		land surface		Measure		11/14/2023			
Pumping Level (below land surface)										40 ft.		1 hrs.		Pumping at		25 g.p.m.			
Wellhead Completion										Pitless adapter manufacturer			Model						
☐ Casing Protection										☐ 12 in. above grade									
☐ At-grade (Environmental Wells and Borings ONLY)																			
Grouting Information										Well Grouted?		☒ Yes ☐ No ☐ Not Specified							
Material										Amount		From		To					
cuttings												50 ft.		80 ft.					
bentonite										6 Sacks				ft. 50 ft.					
Nearest Known Source of Contamination										50 feet		North Direction		Septic tank/drain field		Type			
Well disinfected upon completion?										☒ Yes ☐ No									
Pump ☒ Not Installed										Date Installed									
Manufacturer's name																			
Model Number										HP		Volt							
Length of drop pipe										ft		Capacity		g.p.		Typ			
Abandoned										Does property have any not in use and not sealed well(s)?			☐ Yes ☒ No						
Variance										Was a variance granted from the MDH for this well?			☐ Yes ☒ No						
Miscellaneous										First Bedrock			Aquifer						
Last Strat													Depth to Bedrock			ft			
Located by																			
Locate Method																			
System										UTM - NAD83, Zone 15, Meters		X		Y					
Unique Number Verification															Input Date				
Angled Drill Hole																			
Well Contractor										Bills Well Drilling, Inc.			2123		GRAHAM, KELLY				
Licensee Business													Lic. or Reg. No.		Name of Driller				