

879600

County Pine
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 05/24/2024
Received Date 12/22/2023

Well Name LIFE STYLE					Township 39	Range 22	Dir W	Section 29	Subsection BDB	Well Depth 140 ft.			Depth Completed 140 ft.			Date Well Completed 11/03/2023			
Elevation					Elev. Method					Drill Method Non-specified Rotary			Drill Fluid Bentonite						
Address										Use domestic			Status Active						
Well 3102 MEADOW LARK CV GRASSTON MN 56030										Well Hydrofractured? Yes ☐ No ☒			From To						
Contact LITCHFIELD MN 55355										Casing Type Single casing			Joint						
Stratigraphy Information										Drive Shoe? Yes ☐ No ☐			Above/Below						
Geological Material					From	To (ft.)	Color	Hardness		Casing Diameter			Weight			Hole Diameter			
SAND					0	15	BROWN	SOFT		4 in. To 130 ft. 2.25 lbs./ft.			7.8 in. To 140 ft.						
CLAY ROCKS					15	130	BROWN	HARD											
AQUIFER					130	140	BROWN	SOFT											
										Open Hole			From	ft.	To	ft.			
										Screen? ☒	Type plastic		Make JET STREAM						
										Diameter	Slot/Gauze	Length	Set						
										4 in.	10	10 ft.	130 ft.		140 ft.				
										Static Water Level									
										14 ft.	land surface		Measure		11/03/2023				
										Pumping Level (below land surface)									
										120 ft.	1 hrs.	Pumping at		10 g.p.m.					
										Wellhead Completion									
										Pitless adapter manufacturer			Model						
										☐	Casing Protection		☐ 12 in. above grade						
										☐	At-grade (Environmental Wells and Borings ONLY)								
										Grouting Information			Well Grouted?		☒ Yes	☐ No	☐ Not Specified		
										Material		Amount		From	To				
										cuttings				50 ft.	130 ft.				
										bentonite		6 Sacks		ft. 50 ft.					
										Nearest Known Source of Contamination									
										50 feet	Southwes Direction		Septic tank/drain field		Type				
										Well disinfected upon completion?			☒ Yes	☐ No					
										Pump ☒	Not Installed		Date Installed						
										Manufacturer's name									
										Model Number		HP		Volt					
										Length of drop pipe		ft	Capacity	g.p.	Typ				
										Abandoned									
										Does property have any not in use and not sealed well(s)?			☐ Yes	☒ No					
										Variance									
										Was a variance granted from the MDH for this well?			☐ Yes	☒ No					
										Miscellaneous									
										First Bedrock		Aquifer							
										Last Strat		Depth to Bedrock		ft					
										Located by									
										Locate Method									
										System		UTM - NAD83, Zone 15, Meters		X	Y				
										Unique Number Verification			Input Date						
										Angled Drill Hole									
										Well Contractor									
										Bills Well Drilling, Inc.		2123		GRAHAM, KELLY					
										Licensee Business		Lic. or Reg. No.		Name of Driller					