

879840

County Dakota
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 05/18/2026
Received Date 03/18/2026

Well Name WEBER, RON					Township 113	Range 17	Dir W	Section 4	Subsection DAD	Well Depth 250 ft.		Depth Completed 250 ft.		Date Well Completed 04/30/2025							
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Foam									
Address C/W 22651 LILLEUEI AV HASTINGS MN 55033										Use irrigation		Status Active									
Stratigraphy Information Geological Material From To (ft.) Color Hardness TOPSOIL 0 1 BLACK SOFT CLAY 1 12 BROWN SOFT LIME 12 250 YEL/GRY HARD										Well Hydrofractured?		Yes ☐		No ☒		From		To			
										Casing Type		Single casing		Joint		Welded					
										Drive Shoe?		Yes ☒		No ☐		Above/Below					
										Casing Diameter		12 in. To		Weight		105 ft. 49.57 lbs./ft.		Hole Diameter		24 in. To 12 ft.	
																				17 in. To 250 ft.	
										Open Hole		From 105 ft.		To 250 ft.							
										Screen?		☐		Type				Make			
										Static Water Level		60 ft.		land surface Measure 04/16/2025							
										Pumping Level (below land surface)		140 ft.		6 hrs. Pumping at 500 g.p.m.							
										Wellhead Completion		Pitless adapter manufacturer 12X6 Model DISCHARGE									
										☒ Casing Protection		☒ 12 in. above grade									
										☐ At-grade (Environmental Wells and Borings ONLY)											
										Grouting Information		Well Grouted? ☒ Yes ☐ No ☐ Not Specified									
										Material		Amount		From To							
										neat cement		6 Cubic yards		ft. 105 ft.							
										Nearest Known Source of Contamination		200 feet West Direction		Other Type							
										Well disinfected upon completion?		☒ Yes ☐ No									
										Pump		☐ Not Installed Date Installed 04/30/2025									
										Manufacturer's name		AY MCDONALD									
										Model Number		500S50HP8 HP 50		Volt 460							
										Length of drop pipe		168 ft Capacity 500 g.p.		Typ Submersible							
										Abandoned		Does property have any not in use and not sealed well(s)?		☐ Yes ☒ No							
										Variance		Was a variance granted from the MDH for this well?		☐ Yes ☒ No							
										Miscellaneous		First Bedrock		Aquifer							
										Last Strat		Depth to Bedrock		ft							
										Located by											
										Locate Method											
										System		UTM - NAD83, Zone 15, Meters		X Y							
										Unique Number Verification				Input Date							
										Angled Drill Hole											
										Well Contractor		Kimmes Bauer Well Drilling, 1540		ILLA, C.							
										Licensee Business		Lic. or Reg. No.		Name of Driller							