

881298

County Douglas
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/29/2025
Update Date 05/29/2025
Received Date 12/05/2024

Well Name FERNHOLZ,	Township 127	Range 39	Dir W	Section 19	Subsection DDD	Well Depth 110 ft.	Depth Completed 105 ft.	Date Well Completed 07/23/2024
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Qwik gel	
Address						Use domestic	Status Active	
Well 16051 FREEBORN LA SW KENSINGTON MN 56343						Well Hydrofractured? Yes ☐ No ☒ From To		
Contact 7271 SANDY HILL RD SW HOFFMAN MN 56339						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
CLAY		0	62	BROWN	MEDIUM	4 in. To 99 ft. lbs./ft. 8 in. To 110 ft.		
CLAY		62	99	BLUE	MEDIUM			
SAND		99	105	GRAY	SOFT			
CLAY		105	110	BLUE	MEDIUM			
Open Hole						From	ft.	To ft.
Screen? ☒						Type stainless	Make JOHNSON	
Diameter						Slot/Gauze	Length	Set
4 in.						7	6 ft.	ft. ft.
Static Water Level								
40 ft.						land surface	Measure	07/23/2024
Pumping Level (below land surface)								
105 ft.						2 hrs.	Pumping at	30 g.p.m.
Wellhead Completion								
Pitless adapter manufacturer						Model		
☐ Casing Protection						☒ 12 in. above grade		
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted?	☒ Yes	☐ No ☐ Not Specified
Nearest Known Source of Contamination								
50 feet						Northwes Direction		Other Type
Well disinfected upon completion?						☒ Yes	☐ No	
Pump ☐ Not Installed						Date Installed	07/03/2024	
Manufacturer's name						FPS		
Model Number						HP	0.5	Volt
Length of drop pipe						ft	Capacity	g.p. Typ Submersible
Abandoned								
Does property have any not in use and not sealed well(s)?						☐ Yes	☒ No	
Variance								
Was a variance granted from the MDH for this well?						☐ Yes	☒ No	
Miscellaneous								
First Bedrock						Aquifer		
Last Strat						Depth to Bedrock ft		
Located by								
Locate Method								
System UTM - NAD83, Zone 15, Meters						X	Y	
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor								
Darin Weisel Well Service						1359	WEISEL, OWEN.	
Licensee Business						Lic. or Reg. No.	Name of Driller	