

881991

County Otter Tail
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 01/15/2026
Update Date 01/15/2026
Received Date 09/12/2025

Well Name CAMPANA, NICK 134					Township 39	Range W 7	Dir BDD	Subsection BDD	Well Depth 72 ft.				Depth Completed 70 ft.				Date Well Completed 03/07/2025															
Elevation					Elev. Method					Drill Method Non-specified Rotary				Drill Fluid Qwik gel																		
Address									Use domestic				Status Active																			
Well 40110 BLUE HARON LO RICHVILLE MN 56576									Well Hydrofractured? Yes ☐ No ☒				From To																			
Contact 3733 ST CHARLES CI SARASOTA FL 34233									Casing Type Single casing				Joint																			
Stratigraphy Information									Drive Shoe? Yes ☐ No ☒				Above/Below																			
Geological Material					From	To (ft.)	Color	Hardness	Casing Diameter				Weight				Hole Diameter															
TOP SOIL					0	2	BLACK	SOFT	4 in. To 60 ft.				lbs./ft.				6.7 in. To 72 ft.															
SAND					2	21	GRAY	SOFT																								
CLAY					21	57	GRAY	SOFT																								
SAND					57	72	GRAY	SOFT																								
									Open Hole				From				ft.				To				ft.							
									Screen? ☒				Type plastic				Make BIGFOOT															
									Diameter				Slot/Gauze				Length				Set											
									4 in.				15				10 ft.				60 ft. 70 ft.											
									Static Water Level				4 ft.				land surface				Measure				03/07/2025							
									Pumping Level (below land surface)				60 ft.				1 hrs.				Pumping at				100 g.p.m.							
									Wellhead Completion				Pitless adapter manufacturer				BAKER				Model				BULLDOG4X1							
									☐ Casing Protection				☐ 12 in. above grade																			
									☐ At-grade (Environmental Wells and Borings ONLY)																							
									Grouting Information				Well Grouted? ☒ Yes ☐ No ☐ Not Specified																			
									Material				Amount				From				To											
									other				6 Sacks				ft. 50 ft.															
									Nearest Known Source of Contamination				50 feet				South Direction				<u>Septic tank/drain field</u>				Type							
									Well disinfected upon completion?				☒ Yes ☐ No																			
									Pump ☐ Not Installed				Date Installed				03/07/2025															
									Manufacturer's name				GOULD																			
									Model Number				10CS05-				HP				0.5				Volt				230			
									Length of drop pipe				40 ft				Capacity				10 g.p.				Typ				Submersible			
									Abandoned				Does property have any not in use and not sealed well(s)?				☐ Yes ☒ No															
									Variance				Was a variance granted from the MDH for this well?				☐ Yes ☒ No															
									Miscellaneous				First Bedrock				Aquifer															
									Last Strat				Depth to Bedrock								ft											
									Located by				Locate Method																			
									System				UTM - NAD83, Zone 15, Meters				X				Y											
									Unique Number Verification								Input Date															
									Angled Drill Hole																							
									Well Contractor				Geo Tech of Minnesota, Inc.				1733				NASH, J											
									Licensee Business				Lic. or Reg. No.				Name of Driller															
Remarks																																