

882069

County Meeker

Quad

Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/16/2026
Update Date 04/16/2026
Received Date 01/02/2026

Well Name WIMMER,	Township 119	Range 30	Dir Section W 14	Subsection BBA	Well Depth 93 ft.	Depth Completed 93 ft.	Date Well Completed 06/03/2025		
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid Bentonite			
Address C/W 67993 260TH ST DARWIN MN 55324					Use domestic	Status Active			
					Well Hydrofractured? Yes ☐ No ☒ From To				
Stratigraphy Information Geological Material From To (ft.) Color Hardness CLAY & ROCKS 0 75 GRAY MEDIUM SAND GRAVEL 75 93 VARIED SOFT					Casing Type Single casing	Joint Solvent Welded			
					Drive Shoe? Yes ☐ No ☐ Above/Below				
					Casing Diameter		Weight	Hole Diameter	
					4 in. To 88 ft.		lbs./ft.	8 in. To 50 ft.	
								6.2 in. To 93 ft.	
Open Hole					From ft.	To ft.			
Screen? ☒					Type unknown	Make JOHNSON			
Diameter Slot/Gauze Length Set									
3 in. 20 4 ft. 88 ft. 92 ft.									
Static Water Level									
1 ft. land surface					Measure	06/03/2025			
Pumping Level (below land surface)									
25 ft. 1 hrs. Pumping at					40	g.p.m.			
Wellhead Completion									
Pitless adapter manufacturer BAKERMONITOR Model BMOPS45S40									
☐ Casing Protection ☐ 12 in. above grade									
☐ At-grade (Environmental Wells and Borings ONLY)									
Grouting Information					Well Grouted? ☒ Yes ☐ No ☐ Not Specified				
Material Amount From To									
other 60 ft. 93 ft.									
bentonite 6 Sacks ft. 60 ft.									
Nearest Known Source of Contamination									
53 feet North Direction					Septic tank/drain field Type				
Well disinfected upon completion? ☐ Yes ☐ No									
Pump ☐ Not Installed Date Installed 06/06/2025									
Manufacturer's name FLOWISE									
Model Number FW10S05 HP 0.5 Volt 230									
Length of drop pipe 40 ft Capacity 10 g.p. Typ Submersible									
Abandoned									
Does property have any not in use and not sealed well(s)? ☒ Yes ☐ No									
Variance									
Was a variance granted from the MDH for this well? ☐ Yes ☒ No									
Miscellaneous									
First Bedrock					Aquifer				
Last Strat					Depth to Bedrock	ft			
Located by									
Locate Method									
System UTM - NAD83, Zone 15, Meters X Y									
Unique Number Verification					Input Date				
Angled Drill Hole									
Well Contractor									
LTP Enterprises, Inc. 2157 SCHULTZ, B									
Licensee Business Lic. or Reg. No. Name of Driller									