

882099

County Rice
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/24/2026
Update Date 04/24/2026
Received Date 01/05/2026

Well Name MCADAM, CADE 110					Township 21					Range W 22					Dir Section DAD					Subsection					Well Depth 120 ft.					Depth Completed 120 ft.					Date Well Completed 10/24/2025				
Elevation					Elev. Method					Drill Method Non-specified Rotary					Drill Fluid Water					Use domestic					Status Active														
Address C/W 18824 CANBY WA FARIBAULT MN 55021																																							
Well Hydrofractured? Yes ☐ No ☒ From To																																							
Casing Type Single casing Joint Welded																																							
Drive Shoe? Yes ☒ No ☐ Above/Below																																							
Stratigraphy Information																																							
Geological Material										From					To (ft.)					Color					Hardness														
CLAY										0					25					BROWN					SOFT														
GRAVEL + CLAY										25					78					GRAY					SOFT														
CLAY										78					107					GRAY					MEDIUM														
LIMESTONE										107					120					GRAY					HARD														
Open Hole From 108 ft. To 120 ft.																																							
Screen? ☐ Type Make																																							
Static Water Level 56 ft. land surface Measure 10/24/2025																																							
Pumping Level (below land surface) 100 ft. 2 hrs. Pumping at 20 g.p.m.																																							
Wellhead Completion Pitless adapter manufacturer MONITOR Model ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)																																							
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite 6 Sacks ft. 108 ft.																																							
Nearest Known Source of Contamination 150 feet East Direction Septic tank/drain field Type Well disinfected upon completion? ☒ Yes ☐ No																																							
Pump ☐ Not Installed Date Installed 10/30/2025 Manufacturer's name J-CLASS Model Number HP 0.75 Volt 230 Length of drop pipe 100 ft Capacity 10 g.p. Typ Submersible																																							
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																																							
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No																																							
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date																																							
Angled Drill Hole																																							
Well Contractor Bemis Well Drilling, LLP 1434 BEMIS, B Licensee Business Lic. or Reg. No. Name of Driller																																							

Remarks