

882100

County Rice
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/24/2026
Update Date 04/24/2026
Received Date 01/05/2026

Well Name BRAUN, GARY					Township 110	Range 22	Dir Section W 15	Subsection DCB	Well Depth 250 ft.		Depth Completed 250 ft.		Date Well Completed 11/24/2025																	
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Water																		
Address C/W 17705 ISABELLA TR KILKENNY MN 56052									Use domestic		Status Active																			
Stratigraphy Information <table><tr><td>Geological Material</td><td>From</td><td>To (ft.)</td><td>Color</td><td>Hardness</td></tr><tr><td>CLAY</td><td>0</td><td>70</td><td>BROWN</td><td>MEDIUM</td></tr><tr><td>CLAY-SAND</td><td>70</td><td>234</td><td>GRAY</td><td>MEDIUM</td></tr><tr><td>SAND ROCK</td><td>234</td><td>250</td><td>WHITE</td><td>MEDIUM</td></tr></table>									Geological Material	From	To (ft.)	Color	Hardness	CLAY	0	70	BROWN	MEDIUM	CLAY-SAND	70	234	GRAY	MEDIUM	SAND ROCK	234	250	WHITE	MEDIUM	Well Hydrofractured? Yes ☐ No ☒ From To	
									Geological Material	From	To (ft.)	Color	Hardness																	
									CLAY	0	70	BROWN	MEDIUM																	
									CLAY-SAND	70	234	GRAY	MEDIUM																	
									SAND ROCK	234	250	WHITE	MEDIUM																	
									Casing Type Single casing ☐ Joint ☐ Welded																					
									Drive Shoe? Yes ☒ No ☐ Above/Below																					
									Casing Diameter 4 in. To 234 ft. 11 lbs./ft.																					
									Hole Diameter 6.5 in. To 234 ft. 4 in. To 250 ft.																					
									Open Hole From 234 ft. To 250 ft.																					
Screen? ☐ Type Make																														
Static Water Level 101 ft. land surface Measure 11/24/2025																														
Pumping Level (below land surface) 140 ft. 2 hrs. Pumping at g.p.m.																														
Wellhead Completion Pitless adapter manufacturer Model BAKER ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)																														
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite 10 Sacks ft. 234 ft.																														
Nearest Known Source of Contamination 80 feet Southwes Direction Septic tank/drain field Type Well disinfected upon completion? ☐ Yes ☐ No																														
Pump ☒ Not Installed Date Installed Manufacturer's name Model Number HP Volt Length of drop pipe ft Capacity g.p. Typ																														
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																														
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No																														
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date																														
Angled Drill Hole																														
Well Contractor Bemis Well Drilling, LLP 1434 BEMIS, B Licensee Business Lic. or Reg. No. Name of Driller																														

Remarks
LOT 6 BLOCK 2 SHIELDS SUNRISE VIEWS