

882429

County Stearns
Quad Elrosa
Quad ID 159C

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 06/25/2024
Update Date 10/16/2025
Received Date 05/28/2024

Well Name ELROSA					Township 124	Range 34	Dir W	Section 9	Subsection DAACBB	Well Depth 66 ft.		Depth Completed 66 ft.		Date Well Completed 05/07/2024					
Elevation 1314					Elev. Method Calc from NED (Natl.Elev.Dataset-30m)					Drill Method Non-specified Rotary		Drill Fluid							
Address C/W 404 2ND AV ELROSA MN 56325										Use domestic		Status Active							
Stratigraphy Information Geological Material From To (ft.) Color Hardness CLAY 0 18 YELLOW MEDIUM CLAY 18 42 BLUE MEDIUM SAND 42 58 YELLOW MEDIUM SAND 58 66 BLUE MEDIUM CLAY 66 66 BLUE MEDIUM										Well Hydrofractured?		Yes ☐		No ☐		From		To	
										Casing Type		Single casing		Joint					
										Drive Shoe?		Yes ☐		No ☐		Above/Below			
										Casing Diameter		Weight		Hole Diameter					
										5 in. To 62 ft.		lbs./ft.		8.7 in. To 66 ft.					
										Open Hole		From ft.		To ft.					
										Screen? ☒		Type stainless		Make JOHNSON					
										Diameter Slot/Gauze Length Set									
										5 in. 15 4 ft. 62 ft. 66 ft.									
										Static Water Level		16 ft. land surface		Measure		04/22/2024			
Pumping Level (below land surface)										60 ft. 1 hrs. Pumping at		40 g.p.m.							
Wellhead Completion										Pitless adapter manufacturer		Model							
☐ Casing Protection										☐ 12 in. above grade									
☐ At-grade (Environmental Wells and Borings ONLY)																			
Grouting Information										Well Grouted? ☒ Yes ☐ No ☐ Not Specified									
Material Amount From To										bentonite 10 Sacks ft. 51 ft.									
Nearest Known Source of Contamination										51 feet South Direction		Septic tank/drain field Type							
Well disinfected upon completion? ☒ Yes ☐ No																			
Pump ☐ Not Installed Date Installed										Manufacturer's name F&W									
Model Number 10S05 HP 0.5 Volt 230																			
Length of drop pipe 40 ft Capacity g.p. Typ Submersible																			
Abandoned										Does property have any not in use and not sealed well(s)?		☐ Yes ☒ No							
Variance										Was a variance granted from the MDH for this well?		☐ Yes ☒ No							
Miscellaneous										First Bedrock		Aquifer							
Last Strat										Depth to Bedrock		ft							
Located by Minnesota Department of Health																			
Locate Method GPS SA Off (averaged) (15 meters)																			
System UTM - NAD83, Zone 15, Meters X 347853 Y 5047345																			
Unique Number Verification Info/GPS from data Input Date 06/24/2024																			
Angled Drill Hole																			
Well Contractor										Wheels Enterprise Inc. 3214 WIELING, J.									
Licensee Business Lic. or Reg. No. Name of Driller																			