

882767

County Hennepin

Quad

Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date

Update Date 02/18/2026

Received Date 09/15/2025

Well Name VOLLRATH,	Township 119	Range 23	Dir W	Section 20	Subsection BBA	Well Depth 220 ft.	Depth Completed 220 ft.	Date Well Completed 01/02/2025		
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite			
Address C/W 22903 STREHLER RD HAMEL MN 55340						Use domestic	Status Active			
						Well Hydrofractured? Yes ☐ No ☒		From To		
Stratigraphy Information Geological Material From To (ft.) Color Hardness CLAY 0 20 TAN CLAY 20 85 GRAY CLAY&GRAVEL 85 120 BROWN CLAY&GRAVEL 120 135 GRAY CLAY 135 150 GRAY CLAY&GRAVEL 150 165 BROWN SHALE 165 190 VARIED SANDSTONE 190 220 GRAY						Casing Type Single casing	Joint Glued			
						Drive Shoe? Yes ☐ No ☒		Above/Below		
						Casing Diameter 4 in. To 213 ft.		Weight lbs./ft.	Hole Diameter 8.2 in. To 60 ft. 7.5 in. To 220 ft.	
						Open Hole From ft. To ft.				
						Screen? ☒	Type other	Make JAYCO		
						Diameter 3 in.	Slot/Gauze 12	Length 7 ft.	Set 213 ft.	220 ft.
						Static Water Level 90 ft. land surface Measure 01/02/2025				
						Pumping Level (below land surface) ft. hrs. Pumping at 60 g.p.m.				
						Wellhead Completion Pitless adapter manufacturer MAASS Model 4' ☐ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)				
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite 7 Sacks 8 ft. 150 ft.				
Nearest Known Source of Contamination feet Direction Type Well disinfected upon completion? ☒ Yes ☐ No										
Pump ☐ Not Installed Date Installed 01/16/2025 Manufacturer's name GRUNDFOS Model Number HP 1.5 Volt 230 Length of drop pipe 120 ft Capacity 20 g.p. Typ Submersible										
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No										
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No										
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date										
Angled Drill Hole										
Well Contractor Stevens Drilling and 2255 JOHNSON, R Licensee Business Lic. or Reg. No. Name of Driller										