

882793

County Wright
Quad Buffalo
Quad ID 122A

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/21/2025
Update Date 04/20/2026
Received Date 04/15/2025

Well Name REINKING,					Township 120	Range 25	Dir W	Section 3	Subsection BDDDCB	Well Depth 111 ft.					Depth Completed 111 ft.					Date Well Completed 01/15/2025				
Elevation 988 ft.					Elev. Method Calc from NED (Natl.Elev.Dataset-30m)					Drill Method Non-specified Rotary					Drill Fluid Bentonite									
Address C/W 5517 DAVERN AV NE BUFFALO MN 55313										Use domestic					Status Active									
Stratigraphy Information Geological Material From To (ft.) Color Hardness CLAY 0 23 TAN GRAVEL 23 50 VARIED CLAY 50 65 GRAY CLAY & GRAVEL 65 75 GRAY GRAVEL & SAND 75 100 VARIED SAND 100 111 BROWN										Well Hydrofractured? Yes ☐ No ☒ From To														
										Casing Type Single casing Joint Glued														
										Drive Shoe? Yes ☐ No ☒ Above/Below														
										Casing Diameter Weight Hole Diameter 4 in. To 104 ft. lbs./ft. 8.2 in. To 60 ft. 7 in. To 111 ft.														
										Open Hole From ft. To ft.														
										Screen? ☒ Type plastic Make JAYCO Diameter Slot/Gauze Length Set 3 in. 18 7 ft. 104 ft. 111 ft.														
										Static Water Level 39 ft. land surface Measure 01/15/2025														
										Pumping Level (below land surface) ft. hrs. Pumping at 60 g.p.m.														
										Wellhead Completion Pitless adapter manufacturer MASS Model 4" ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)														
										Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite 5 Sacks 10 ft. 70 ft.														
Nearest Known Source of Contamination feet Direction Type Well disinfected upon completion? ☒ Yes ☐ No																								
Pump ☐ Not Installed Date Installed 02/05/2025 Manufacturer's name GRUNFAS Model Number SQE HP 1 Volt 220 Length of drop pipe 60 ft Capacity 20 g.p. Typ Submersible																								
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																								
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No																								
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Minnesota Department of Health Locate Method GPS SA Off (averaged) (15 meters) System UTM - NAD83, Zone 15, Meters X 435782 Y 5008894 Unique Number Verification Info/GPS from data Input Date 04/21/2025																								
Angled Drill Hole																								
Well Contractor Stevens Drilling and 2255 STEVENS, M. Licensee Business Lic. or Reg. No. Name of Driller																								
Remarks																								