

882994

County Crow Wing
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 01/06/2026
Received Date 09/22/2025

Well Name PETERSON,	Township 138	Range 28	Dir Section W 24	Subsection DDB	Well Depth 97 ft.	Depth Completed 97 ft.	Date Well Completed 08/27/2025
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address					Use domestic	Status Active	
Contact 2200 405TH AV NW BRAHAM MN 55006					Well Hydrofractured? Yes ☐ No ☒ From To		
Well 40935 OLD GRADE RD PINE RIVER MN 56474					Casing Type Single casing Joint		
Stratigraphy Information					Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material From To (ft.) Color Hardness					Casing Diameter Weight Hole Diameter		
SAND/GRAVEL 0 37 BROWN MEDIUM					4 in. To 77 ft. 1.88 lbs./ft. 8.7 in. To 97 ft.		
CLAY/GRAVEL 37 75 BROWN MEDIUM							
SAND/GRAVEL 75 97 BROWN M.HARD							
					Open Hole From ft. To ft.		
					Screen? ☒ Type other Make NORTHERN		
					Diameter Slot/Gauze Length Set		
					4 in. 16 20 ft. 77 ft. 97 ft.		
					Static Water Level		
					47 ft. land surface Measure 08/27/2025		
					Pumping Level (below land surface)		
					90 ft. 3 hrs. Pumping at 12 g.p.m.		
					Wellhead Completion		
					Pitless adapter manufacturer BAKER Model BOLT-ON		
					☐ Casing Protection ☒ 12 in. above grade		
					☐ At-grade (Environmental Wells and Borings ONLY)		
					Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
					Material Amount From To		
					bentonite 8 Sacks ft. 60 ft.		
					Nearest Known Source of Contamination		
					51 feet Southwes Direction Other Type		
					Well disinfected upon completion? ☒ Yes ☐ No		
					Pump ☐ Not Installed Date Installed 08/27/2025		
					Manufacturer's name FLOW+WISE		
					Model Number 4F10S05305 HP 0.5 Volt 220		
					Length of drop pipe 80 ft Capacity 10 g.p. Typ Submersible		
					Abandoned		
					Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
					Variance		
					Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
					Miscellaneous		
					First Bedrock Aquifer		
					Last Strat Depth to Bedrock ft		
					Located by		
					Locate Method		
					System UTM - NAD83, Zone 15, Meters X Y		
					Unique Number Verification Input Date		
					Angled Drill Hole		
					Well Contractor		
					Lambert Water Wells, Inc. 2119 LAMBERT, L		
					Licensee Business Lic. or Reg. No. Name of Driller		