

883203

County Washington
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 11/20/2025
Received Date 07/01/2024

Well Name CUSTOM ONE					Township 28	Range 21	Dir Section W 32	Subsection BBD	Well Depth 320 ft.		Depth Completed 320 ft.		Date Well Completed 06/20/2024			
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Foam				
Address									Use domestic		Status Active					
Contact 5097 WOODLANE AL WOODBURY MN 55125									Well Hydrofractured? Yes ☐ No ☒		From		To			
Well 511 WOODLANE AL WOODBURY MN 55125									Casing Type Single casing		Joint Welded					
Stratigraphy Information									Drive Shoe? Yes ☒ No ☐		Above/Below					
Geological Material		From	To (ft.)	Color	Hardness				Casing Diameter		Weight		Hole Diameter			
CLAY		0	40	BROWN	MEDIUM				4 in. To 280 ft. 10.79 lbs./ft.		12 in. To 40 ft.					
LIME		40	65	GRAY	HARD						8 in. To 280 ft.					
SHALE		65	72	GREEN	MEDIUM						4 in. To 320 ft.					
SANDROCK		72	185	WHITE	MEDIUM											
LIME		185	320	BROWN	HARD											
									Open Hole		From 280 ft.		To 320 ft.			
									Screen? ☐		Type		Make			
Static Water Level									205 ft.		land surface		Measure 06/20/2024			
Pumping Level (below land surface)									260 ft.		2 hrs.		Pumping at 30 g.p.m.			
Wellhead Completion									Pitless adapter manufacturer		BAKER		Model OPS45S4CO			
									☐ Casing Protection		☐ 12 in. above grade					
									☐ At-grade (Environmental Wells and Borings ONLY)							
Grouting Information									Well Grouted?		☒ Yes ☐ No ☐ Not Specified					
Material									Amount		From		To			
neat cement									5 Cubic yards		ft. 280		ft.			
Nearest Known Source of Contamination									75 feet		South Direction		Septic tank/drain field Type			
Well disinfected upon completion?									☒ Yes ☐ No							
Pump ☐ Not Installed									Date Installed		06/20/2024					
Manufacturer's name									FLINT & WALLING							
Model Number									4F27S50		HP 5		Volt 230			
Length of drop pipe									252 ft		Capacity 27 g.p.		Typ Submersible			
Abandoned									Does property have any not in use and not sealed well(s)?		☐ Yes ☒ No					
Variance									Was a variance granted from the MDH for this well?		☐ Yes ☒ No					
Miscellaneous									First Bedrock		Aquifer					
Last Strat									Depth to Bedrock				ft			
Located by									Locate Method							
System									UTM - NAD83, Zone 15, Meters		X		Y			
Unique Number Verification											Input Date					
Angled Drill Hole																
Well Contractor									R & B Services, LLC		2888		FRITZ, R.			
Licensee Business									Lic. or Reg. No.				Name of Driller			