

884100

County Chisago
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 02/03/2026
Received Date 12/24/2025

Well Name DOWELL, BARB					Township 33	Range 20	Dir W	Section 3	Subsection AAD
Elevation					Elev. Method				
Address C/W 29810 GLADER RN LINDSTROM MN									
Stratigraphy Information									
Geological Material		From	To (ft.)	Color	Hardness				
CLAY		0	26	TAN	MEDIUM				
SAND+GRAVEL		26	58	BROWN	SOFT				
CLAY, GRAVEL		58	95	BRN/RED	MEDIUM				
SANDGRAVEL		95	140	BROWN	SOFT				
Well Depth 140 ft.									
Depth Completed 140 ft.									
Date Well Completed 12/16/2025									
Drill Method Non-specified Rotary					Drill Fluid Qwik gel				
Use domestic					Status Active				
Well Hydrofractured? Yes ☐ No ☒ From To									
Casing Type Single casing					Joint Glued				
Drive Shoe? Yes ☐ No ☒ Above/Below									
Casing Diameter 4 in. To					Weight 135 ft. lbs./ft.			Hole Diameter 7.8 in. To 140 ft.	
Open Hole From ft. To ft.									
Screen? ☒		Type stainless		Make JOHNSON					
Diameter		Slot/Gauze		Length		Set			
4 in.		20		5 ft.		135 ft.		140 ft.	
Static Water Level 51 ft. land surface Measure 06/03/2025									
Pumping Level (below land surface) 100 ft. 3 hrs. Pumping at 20 g.p.m.									
Wellhead Completion Pitless adapter manufacturer AQUASEAL Model T-1 ☒ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)									
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified									
Material		Amount		From		To			
other		7 Sacks		127		ft. 140		ft.	
other		7 Sacks				ft. 127		ft.	
Nearest Known Source of Contamination 50 feet Southwes Direction Sewer Type Well disinfected upon completion? ☒ Yes ☐ No									
Pump ☐ Not Installed Date Installed 06/03/2025 Manufacturer's name FLINT + WALLING Model Number 4F10S05305 HP 0.5 Volt 230 Length of drop pipe 80 ft Capacity 10 g.p. Typ Submersible									
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No									
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No									
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date									
Angled Drill Hole									
Well Contractor Husnik Well Drilling 1646 HUSNIK, C Licensee Business Lic. or Reg. No. Name of Driller									