

884249

County Fillmore
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 02/11/2026
Received Date 01/02/2026

Well Name DROGEMULLER, 104					Township 10		Range W 20		Dir Section BCD		Subsection		Well Depth 280 ft.		Depth Completed 280 ft.		Date Well Completed 12/12/2025						
Elevation					Elev. Method					Drill Method Non-specified Rotary				Drill Fluid Foam									
Address												Use domestic		Status Active									
Contact 216 UNION ST CHATFIELD MN 55923												Well Hydrofractured? Yes ☐ No ☒				From		To					
Stratigraphy Information												Casing Type Step down		Joint Welded									
Geological Material												Drive Shoe? Yes ☒ No ☐		Above/Below									
CLAY												4 in. To		236 ft.		lbs./ft.		12 in. To		10 ft.			
LIMESTONE												8 in. To		10 ft.		lbs./ft.		8 in. To		236 ft.			
SANDSTONE												4 in. To						4 in. To		280 ft.			
												Open Hole		From 236 ft.		To 280 ft.							
												Screen? ☐		Type		Make							
												Static Water Level											
												52 ft.		land surface		Measure		10/02/2025					
												Pumping Level (below land surface)											
												62 ft.		2 hrs.		Pumping at		15 g.p.m.					
												Wellhead Completion											
												Pitless adapter manufacturer		BAKER		Model		4X5					
												☐ Casing Protection		☐ 12 in. above grade									
												☐ At-grade (Environmental Wells and Borings ONLY)											
												Grouting Information		Well Grouted?		☒ Yes ☐ No ☐ Not Specified							
												Material		Amount		From		To					
												pearock		2 Cubic yards		10 ft.		185 ft.					
												neat cement		5 Cubic yards				236 ft.					
												Nearest Known Source of Contamination											
												50 feet		Direction				Type					
												Well disinfected upon completion?		☒ Yes ☐ No									
												Pump ☐ Not Installed		Date Installed		12/12/2025							
												Manufacturer's name		GRUNDFOS									
												Model Number		15SQE10-		HP		1		Volt		230	
												Length of drop pipe		160 ft		Capacity		15 g.p.		Typ		Submersible	
												Abandoned											
												Does property have any not in use and not sealed well(s)?		☐ Yes ☒ No									
												Variance											
												Was a variance granted from the MDH for this well?		☐ Yes ☒ No									
												Miscellaneous											
												First Bedrock				Aquifer							
												Last Strat				Depth to Bedrock				ft			
												Located by											
												Locate Method											
												System		UTM - NAD83, Zone 15, Meters		X		Y					
												Unique Number Verification						Input Date					
												Angled Drill Hole											
												Well Contractor											
												Thein Well Rochester, Inc.		2641		HANSON, B							
												Licensee Business		Lic. or Reg. No.		Name of Driller							